



## รายการอ้างอิง

ภาษาไทย

- กิตติ โสภณศักดิ์ , "การบำบัดน้ำเสียจากโรงงานสุราโดยขบวนการอาร์บีซีที่มีการหมุนเวียนน้ำทิ้ง" , วิทยานิพนธ์ปริญญาโทบริหารธุรกิจ , ภาควิชาวิศวกรรมสุขาภิบาล บัณฑิตวิทยาลัย จุฬาลงกรณ์มหาวิทยาลัย , 2524.
- พิพัฒน์ ภิรมย์คุณ , "การศึกษาเพื่อเปรียบเทียบประสิทธิภาพในการกำจัดน้ำทิ้งของไบโอดิสค์และสับเมอจดรัม" , วิทยานิพนธ์ปริญญาโทบริหารธุรกิจ , ภาควิชาวิศวกรรมสิ่งแวดล้อม บัณฑิตวิทยาลัย จุฬาลงกรณ์มหาวิทยาลัย , 2523.
- วรวุฒิ ชัยศิริรัตน์ , "การกำจัดน้ำเสียของโรงพยาบาลราชวิถีด้วยระบบจานหมุนชีวภาพ" , วิทยานิพนธ์ปริญญาโทบริหารธุรกิจ , ภาควิชาเทคโนโลยีสิ่งแวดล้อม บัณฑิตวิทยาลัย มหาวิทยาลัยมหิดล , 2531.
- ศุภมิตร จันทร์คำฮ้าย , "การกำจัดน้ำเสียที่มีพีเอชต่ำโดยใช้ไบโอจดรัม." วิทยานิพนธ์ปริญญาโทบริหารธุรกิจ , ภาควิชาวิศวกรรมสิ่งแวดล้อม บัณฑิตวิทยาลัย จุฬาลงกรณ์มหาวิทยาลัย , 2535.
- สุเมธ ขวเดช "ลักษณะสมบัติเมือกจุลินทรีย์" , สัมมนาทางวิชาการระดับชาติ เทคโนโลยีน้ำและน้ำเสีย (รศ.ดร.ธงชัย พรรณสวัสดิ์) , คณะวิศวกรรมศาสตร์ จุฬาลงกรณ์มหาวิทยาลัย , 2530.

ภาษาอังกฤษ

- Abraham Pano and Middlebrooks Joe, E., "Kinetics of Carbon and Ammonia Nitrogen Removal in RBCs," Jour. Water Poll. Control Fed. 55 (July 1983) 956.
- Alexander Regent, "Small RBCs Logging Hours in Yukoslavia", Water and Sewage Works (August 1980) 42.
- American Public Health Association, Standard Methods for the Examination of Water and Wastewater Ed, American Public (Helth Association Washington, D.C 1992
- Antonie, R.L., "Response of the Bio-Disc Process to Fluctuating Wastewater Flows", Proc.25th Industrial Waste Conference (Purdue University : Lafayette, 1970) P. 427.

- \_\_\_\_\_ R.L. and Hynek, R.J., "Operating Experience with Bio-Surf Process Treatment of Food-Processing Wastes", Proc. 28th Industrial Waste Conference" (Purdue University : Lafayette, 1973) P. 849.
- \_\_\_\_\_ R.L., Klage, D.L. and Mielke, J.H., "Evaluation of a Rotating Disk Wastewater Treatment Plant" Jour Water Poll. Control Fed. 46 (1974) 498.
- \_\_\_\_\_ R.L., "Nitrification of Activated Sludge Effluent : Bio-Surf Process", Water and Sewage Works 121 (November 1974) 44.
- \_\_\_\_\_ R.L., "Nitrification of Activated Sludge Effluent : Bio-Surf Process", Water and Sewage Works 121 (December 1974) 55.
- \_\_\_\_\_ R.L., Fixed Biological Surface-Wastewater Treatment (Ohio : CRC Press Inc., 1976)
- Bandy, J.T. and Scholze, R.J., "Effects of Periodically reversing the Direction of flow through an RBC", Jour Water Poll. Control Fed. 55 (December 1983) 1457.
- Barnes, D., Bliss, P.J., Gould, B. Wand Vallentine , H.R. Water and Wastewater Engineering Systems (Pitman Publishing inc., 1981
- Bintanja, H.H.J., Brunsmam, J.J. and Boelhouwer, C., "The Use of Oxygen in a Rotating Disc Process," Water Research 10 (1976) 561.
- Birks, C.W. and Hynek, R.J. "Treatment of Cheese Processing Wastes by the Bio-Disc Process," Proc. 26th Industrial waste Conference (Purdue University : Lafayette, 1971) P. 89.
- Blanc, C.F. O'Shaughnessy, J.C. and Miller, C.H., "Treatment of Bottling Plant Wastewater with Rotating Biological Contactors" Proc. 33rd Industrial Waste Conference (Purdue University : Lafayette,) P. 614.
- Busch, A.W. and Hughmark, G.A., "Trickling Filter Theories" Proc. 23rd Industrial Waste Conference (Purdue University : Lafayette, 1968) P. 766.
- Ching-San Huang, "Nitrification Kinetics and Its RBC Application," ASCE of Environmental Engineering 108 (June 1982) 473.

- Chittenden, J.A. and Wells, W.J., "Rotating Biological Contactors Following Anaerobic Lagoons," Jour Water Poll. Control Fed. 43 (1971) 746.
- Choung, Y.K., Bae, B.H. , and Ahn, K.H., "Treatment of Phenolic Wastewater using Rotation Biological Contactors" Water Poll Control in Asia P. 685
- Chudoba, J.W., Kucman, K. and Proske, L., "Control of Activated Sludge Filamentous Bulking-VII. Effect of anoxic Condition," Water Research 21 (1987) 1447.
- Clark, J.H., Moseng, E.M., Asano, T., Washington State University and Pullman, "Performance of a Rotating Biological Contactor under Varying Wastewater Flow." Jour. Water Poll. Control Fed. 50 (May 1978) 896.
- Collins, A.G., Clarkson, W.,W. and Vrona, M., " Fixed-Film Biological Nitrification of a Strong Industrial Waste", Jour Water Poll. Control Fed. 60 (April 1988) 499.
- Enayatullah, "Perfomance of a Rotating Drum Filter in Treatment of Wastewater in the Tropics, "Master's Thesis, Department of Environmental Engineering, AIT , 1995
- Friedman, A.A., Robbins, L.E. and Woods, R.C., "Effect of Disk Rotational Speed on Biological Contactor Efficiency ", Jour. Water Poll. Control Fed. 51(November 1979) 2678.
- \_\_\_\_\_ A.A. Woods, R.C. and Wilkey, R.C., "Kinetics Response of Rotating Biological Contactors", Proc. 31st Industrial Waste Conference (Purdue University : Lafayette, 1976) P. 420.
- \_\_\_\_\_ A.A., Robbins, L.E. and Woods, R.C., "Effects of Disk Rotational Speed on RBC Efficiency," Proc. 33rd Industrial Waste Conference (Purdue University : Lafayette, 1978) P. 73'
- Gillespie, W.J., Marshall, D.W. and Springer, A.M., "A Pilot Scale Evaluation of Rotating Biological Surface Treatment of Pulp and Paper Mill Wastes," Proc. 29th Industrial waste Conference (Purdue University : Lafayette, 1974) P. 1026.

- Graves, B.Q., Scott David. JR., Cook, E.E. and Dabra, Y.A., "Aerobic sludge Digestion at a Trickleing Filter Waste Treatment Plant", Proc. 27th Industrial Waste Conference (Purdue University : Lafayette, 1972) P. 501.
- Hammer, M.J., "Rotating Biological Contactors Treating Combined Domestic and Cheese - Processing Wasterwaters", Proc. 37th Industrial Waste Conference (Purdue University : Lafayette, 1982) P. 29
- Hao, O. and Hendricks, G.F., "Rotating Biological Reactors Remove Nutrients Part I Water and Sewage works 122 (October 1975) 70.
- \_\_\_\_\_ and Hendricks, G.F., "Retating Biological Reactors Remove Nutrients Part II", Water and Sewage Works 122 (November 1975) 48.
- Hitdelbaugh, J.A. and Miller, R.D., "Operational Problems with Rotating Biological Contactors," Jour Water Poll Control Fed. 53 (August 1981) 1283.
- Hseish Chi Nan , "Variables Affecting the Performance of Biological Disch Filtration Units, "Master's Thesis, Department of Environmental Engineering, AIT. 1992
- Hudson, J.W., Smith, J.P. and Pohland F.G., " Rotating Biological Contactor Treatment of Shellfish Processing Wastewaters," Proc. 31st Industrial Waste Conference (Purdue University : Lafayette, 1976) P. 193
- Jebens, H.J. and Boyle, W.C., "Enhanced Phosphorus Removal in Trickleing Filters," Proc. 26th Industrial Waste (Purdue University : Lafayette, 1971) P. 463.
- Johnson, D.B. and Krill, W.p., " RBC Pilot Plant Treatment of Pretreated Meat Slaughtering/Processing Waste", Proc. 31st Industrial Waste Conference (Purdue University : Lafayette, 1976) P. 733
- Joost, R.H., "Systemation in using the Rotating Biological Surface (RBS) Waste Treatment Process," Proc. 24th Industrial Waste Conference (Purdue University : Lafayette, 1969) P. 365.

- Kehrberger, G.J. and Busch, A.W., "The Effects of Recirculation on the Performance of Trickle Filter Models," Proc. 24th Industrial Waste Conference (Purdue University : Lafayette, 1969) P. 37
- Kinner, N.E. and Eighmy, T.T., "Biological Fixed-Film Systems," Jour Water Poll. Control Fed. 57 (June 1985) 526.
- \_\_\_\_\_ N.E. and Eighmy, T.T., "Biological Fixed-Film System," Jour. water Poll. Control Fed. 58 (June 1986) 498.
- \_\_\_\_\_ N.E. and Eighmy, T.T., "Biological Fixed-Film Systems," Jour Water Poll. Control Fed. 60 (1988) 824.
- Klemetson, S.L., "Biological Filters," Jour. Water Poll. Control Fed. 49 (June 1977) 1001.
- \_\_\_\_\_ and Lang, M.E., "Biological Filters," Jour Water Poll Control Fed. 51 (June 1979) 1183.
- \_\_\_\_\_ Klemetson, S.L., and Lang, M.E., "Treatment of Saline Wastewaters, Using a Rotating Biological Contactor," Jour. Water Poll. Control Fed. 56 (December 1984) 1254'
- Kornegay, B.H. and Andrews, J.F., "Kinetics of Fixed-Film Biological Reactors," Jour. Water Poll. Control Fed. 40 (November 1968) R. 460.
- \_\_\_\_\_ and Andrews, J.F., "Kinetics of Fixed Film Biological Reactors," Proc. 22nd Industrial Waste Conference (Purdue University : Lafayette, 1967) P. 620.
- Labella, S.a., Thaker, I.H. and Tehan, J.E., "Treatment of Winery Wastes by Aerated Lagoon, Activated Sludge and Rotating Biological Contactor", Proc. 27th Industrial Waste Conference (Purdue University : Lafayette, 1972) P. 803
- Lacroix, P.G., and Blood good, D.E., "Computer Simulation of Activated Sludge Plant Operation," Jour Water Poll. Control Fed. 44 (1972) 1778.
- Lue-Hing, C., Obayashi, A.W., Zeng, D.R., Washington, B. and Sawger, B.M., "Biological Nitrification of Sludge Supernatant by Rotating Disks," Jour Water Poll. Control Fed. 48 (1976) 25.

- Miller, R.D., Ryczak, R.S. and Ostrofsky, A., "Phosphorus Removal in a Pilot P.H. Scale Trickling Filter System by Low-level lime Addition to Raw Wastewater," Proc. 32nd Industrial Waste Conference (Purdue University : Lafayette, 1977) P. 325.
- Nair, J.V., "Biological Disc Filtration for Tropical Waste Treatment," master's Thesis, Department of Environmental Engineer, AIT 1971
- Nishidome, Kusuda, T., K. and Tetsuya, K., "Measurements of Dissolved Oxygen in Attached Microbial Films of Rotating Biological Contactor by Oxygen microelectrode Water Pollution Control in Asia P. 305 (Bangkok : T. Panswad, C. Polprasert and k. Yamamoto
- Omen, D.T.M. and Williamson, K.J., "Oxygen Limitation in Heterotrophic Biofilms," Proc. 31st Industrial Waste Conference (Purdue University : Lafayette, 1976) P. 267.
- Patrick J. Lehman, "Start - up and Operating Characteristics of an RBC Facility in a Cold Climate," Jour. Water Poll. Control Fed. 55 (October 1983) 1233.
- Pike, E.B, Carlton-smith, C.H., Evans, R.H. and Harrington, D.W., "Performance of a Rotating Biological Contactors under Field Conditions," Jour Water Poll. Control Fed. (1982) 10.
- Poon Calvin P.C., Chao Ya-Len and Mikucki, W.J., "Factor Controlling Rotating Biological Contactor Performance", Jour. Water Poll Control Fed. 51 (March 1979) 601.
- Chin, H.K., Smith, E.D and Mikucki, W.J., "Upgrading with Rotating Biological Contactor for Ammonia Nitrogen Removal". Jour Water Poll. Control Fed. 53 (July 1981) 1158.
- Reiber, S. and Stensel, S., "Biologically Enhanced Oxygen Transfer in a Fixed-Film System," Jour Water Poll Control fed. 57 (February 1985) 135.
- Roesler, J.F., Smith, R. and Taft, R.A., " A Mathematical Model for a Trickling Filter," Proc. 24th Industrial Waste Conference (Purdue University : Lafayette, 1969) P. 550

- Sack, W.A., Cutright, J. A., Neely, R.g., Soccorsi, P.M. and Carroll, t.a., " Operation of Air Drive Rotating Biological Contactors". Jour Water Control Fed. 58 (November 1986) 1050.
- Shoon - Yuh Chang, Ju-Chang Huang and Yow - Chyun Liu, " Effects of Cd (II) and Cu (II) on a Biofilm System," ASCE of Environmental Engineering 112 (February 1986) 94.
- Shun Dar Lin, Schnepfer, D.H. and Evan, R.L. "A Close look at Changes of BOD 5 in an RBC System," Jour. Water Poll. Control Fed. 58 (July 1986) 757.
- Steimer, B.C.G., "Take a \new Look at the RBG Process Water and Wastes Engineering (May 1979) 41. 103.
- Stover, E.L. and Kincannon, D.F., "Evaluating Rotating Biological Contactor Performance', Water and Sewage Works 123 (March 1976) 88.
- Switzenbaum, M.S., "Biological Filters," Jour Water Poll. Control Fed. 54 (June 1982) 592.
- Tchobanoglous, G, Wastewater Enigneering /Treatment : Disposal , Reused 2nd ed (New Delhi : Metcalf and Eddy Inc., 1982
- Torpey, W.N., Heukelekiam, H., Kaplovsky, A.J.and Epstein, R., "Rotating Disks. with Biological Growths Prepare Wastewater for Disposal or Reuse", Jour Water Poll. control Fed. 43 (1971) 2181.
- Wanner, J., Kucman, K., Ottava, V. and Grau, P., "Effect of Anaerobic Conditions on Activated Sludge Filamentous Bulking in Laboratory Systems," Water Research 21 (1987) 1541.
- Weng, C.N. and Molof, A.H., "Nitrification in the Biological Fixed-Film Rotating Disk System", Jour. Water Poll. Control Fed. 46 (1974) 1674.
- Welch, F,M, " Preliminary Results of a New Approach in the Aerobic Biological Treatment of Highly Concentrated Wastes," Proc. 23rd Industrial Waste Conference (Purdue University; Lafayette, 1968), P. 428.

- Wilson, R.W., Murphy, K.L. and Stephenson, J.P., "Scale up in Rotating Biological Contactor Design," Jour Water Poll Control Fed. 52 (March 1980) 610.
- WPCF Manual Practice No.8, ASCE Manual on Engineering Practice No. 36 Wastewater Treatment Plant Design, 2nd ed. (Lancaster : Lancaster Press Inc, 1982) P. 283.
- Wu, Y.C. and Smith, E.D., " Rotating Biological Contactor System Design", ASCE of Environmental Engineering 108 (June 1982) 578.
- Zeevalkink, J.A., Kelderman, P. and Boelhouwer, C., " Liquid Film Thickness in a Rotating Disc Gas-Liquid Contactor," Water Research 12 ( 1978) 577.
- \_\_\_\_\_ J.A., Kelderman, P., Visser, D.C. and Boelhouwer, C., "Physical Mass Transfer in a Rotating Disc Gas-Liquid Contactor." Water Research 13 (1979) 913.



ศูนย์วิทยทรัพยากร  
จุฬาลงกรณ์มหาวิทยาลัย



ภาคผนวก ก ผลการทดลอง

ศูนย์วิทยทรัพยากร  
จุฬาลงกรณ์มหาวิทยาลัย

## Result of Biodrum Analysis

28-Sep-93

Run	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
1	Influent	519		16	3.2	74		7.25			
Day	1 Drum-1	459	11.56			82.6	11.5	7.32	2.0		
	Drum-2	361	30.44			65	11	7.44	2.7		
	Drum-3	332	36.03			85	29	7.61	3.6		
	Drum-4	258	50.29			73	16	7.62	4.0		
	Effluent-Total	207	60.12			62	ND	7.8	3.9		
	Effluent-Filter	107	79.38	3.92	10.4	6					
	Efficiency (%)	79.38		75.50	-225	91.89					

30-Sep-93

Run	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
1	Influent	517		15	3.6	88		7.31			
Day	3 Drum-1	468	9.48			170	23.5	7.38	2.2		
	Drum-2	306	40.81			125	17.5	7.49	3.0		
	Drum-3	285	44.87			120	30.5	7.65	3.8		
	Drum-4	237	54.16			105	47.4	7.66	4.1		
	Effluent-Total	186	64.02			98	5	7.83	4.0		
	Effluent-Filter	66	87.23	2	2.2	12					
	Efficiency (%)	87.23		86.67	38.89	86.36					

02-Oct-93

Run	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
1	Influent	468		14	3.7	82		7.35			
Day	5 Drum-1	463	1.07			348	30	7.46	4.1		D-1 is the most biofilm thick than others
	Drum-2	272	41.88			246	19	7.72	4.2		
	Drum-3	255	45.51			242	28	8.15	4.4		D-4 is the least
	Drum-4	229	51.07			200	34	7.82	4.6		
	Effluent-Total	128	72.65			184	3	8.05	4.5		
	Effluent-Filter	36	92.31	3	2	16					
	Efficiency (%)	92.31		78.57	45.95	80.49					

04-Oct-93

Run	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
1	Influent	609		18	3.8	86		7.37			
Day	7 Drum-1	616	-1.15			362	35	7.46	3.2		
	Drum-2	340	44.17			233	22	7.83	4.3		
	Drum-3	333	45.32			248	26	7.93	4.6		
	Drum-4	330	45.81			228	21	7.93	4.6		
	Effluent-Total	161	73.56			64	10.5	8	4.2		
	Effluent-Filter	50	91.79	3.4	2	11					
	Efficiency (%)	91.79		81.11	47.37	87.21					

06-Oct-93

Run	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
1	Influent	468		17	3	80		7.36			
Day	9 Drum-1	242	48.29			259	63	7.43	2.9		
	Drum-2	248	47.01			214	30.5	7.84	4.2		
	Drum-3	246	47.44			214	30.5	7.92	4.2		
	Drum-4	166	64.53			180	30	7.95	4.2		
	Effluent-Total	71	84.83			50	15	7.96	4.2		
	Effluent-Filter	25	94.66	5	2	7					
	Efficiency (%)	94.66		33.33	91.25						

08-Oct-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	1 Influent	440		16	3.4	76		7.32			
Day	11 Drum-1	290	34.09			238	68	7.43	3.4		
	Drum-2	287	34.77			148	18	7.78	4.3		
	Drum-3	279	36.59			134	15	7.84	4.6		
	Drum-4	215	51.14			135	16	7.88	4.9		
	Effluent-Total	70	84.09			24	4	7.92	4.8		
	Effluent-Filter	29	93.41	5	0.8	6	0				
	Efficiency (%)	93.41		68.75	76.47	92.11					

10-Oct-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	1 Influent	481		16	2.8	84		7.41			
Day	13 Drum-1	445	7.48			198	41	7.56	3.8		
	Drum-2	281	41.58			176	12	7.88	4.9		
	Drum-3	274	43.04			180	13	7.81	5.0		
	Drum-4	197	59.04			156	11	7.87	5.2		
	Effluent-Total	72	85.03			24	1.4	8.00	5.2		
	Effluent-Filter	32	93.35	2	1	10	0				
	Efficiency (%)	93.35		87.50	64.29	88.10					

12-Oct-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	1 Influent	440		15	3	78		7.30			
Day	15 Drum-1	276	37.27			284	118	7.45	3.7		
	Drum-2	256	41.82			201	85	7.80	4.6		
	Drum-3	127	71.14			196	60	7.92	4.6		
	Drum-4	218	50.45			154	61	7.96	4.8		
	Effluent-Total	65	85.23			49	35	7.96	4.8		
	Effluent-Filter	48	89.09	2	0.9	9					
	Efficiency (%)	89.09		86.67	70.00						

14-Oct-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	1 Influent	452		17	3	80		7.10			D-1 has very good biofilm
Day	17 Drum-1	210	53.54			168	102	7.34	2.5		
	Drum-2	339	25.00			210	84	7.60	4.2		
	Drum-3	221	51.11			174	53	7.78	5.0		
	Drum-4	309	31.64			150	72	7.80	5.1		
	Effluent-Total	56	87.61			43	31	7.97	5.0		
	Effluent-Filter	41	90.93	1.4	0.5	7					
	Efficiency (%)	90.93		91.76	83.33						

16-Oct-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	1 Influent	415		16	3	74		7.08			
Day	19 Drum-1	455	-9.64			236	140	7.18	2.5		
	Drum-2	250	39.76			131	88	7.36	4.2		
	Drum-3	230	44.58			99	50	7.65	4.6		
	Drum-4	392	5.54			97	58	7.79	5.2		
	Effluent-Total	51	87.71			19	20	7.82	5.2		
	Effluent-Filter	30	92.77	3	0.8	4					
	Efficiency (%)	92.7		81.25	73.33						

18-Oct-93

Run	Day	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
1		Influent	571		29	2.8	90		6.96	-		
21		Drum-1	925	-62.00			775	250	7.00	2.5		
		Drum-2	420	26.44			184	81	7.22	4.0		
		Drum-3	167	70.75			99	25	7.64	4.8		
		Drum-4	104	81.79			98	26	7.74	4.9		
		Effluent-Total	49	91.42			15	3	7.77	4.9		
		Effluent-Filter	24	95.80	2	0.8	7		-			
		Efficiency (%)	95.80		93.10	71.43	92.22					

20-Oct-93

Run	Day	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
1		Influent	448		16	3.2	70	-	6.98	5.1		
23		Drum-1	889	-98.4			510	648	7.04	1.6		
		Drum-2	203	54.69			296	113	7.38	3.3		
		Drum-3	117	73.88			129	35	7.52	3.7		
		Drum-4	191	57.37			113	48	7.57	4.2		
		Effluent-Total	43	90.40			18	5	7.65	4.2		
		Effluent-Filter	21	95.31	1	1.9	5	-	-			
		Efficiency (%)	95.31		93.75	40.63	92.86					

22-Oct-93

Run	Day	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
1		Influent	451		18	3	82	-	7.24			
25		Drum-1	818	-81.4			642	680	7.32	1.8		
		Drum-2	148	67.18			48	29	7.50	3.6		
		Drum-3	102	77.38			33	20	7.59	4.2		
		Drum-4	124	72.51			32	10	7.62	4.6		
		Effluent-Total	52	88.47			26	2	7.68	4.6		
		Effluent-Filter	25	94.46	3	1.4	5	-	-			
		Efficiency (%)	94.46		83.33	53.33	93.90					

24-Oct-93

Run	Day	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
1		Influent	533		18	2.6	76	-	6.91	-		
27		Drum-1	496	6.94			151	230	6.97	1.3		
		Drum-2	23	95.68			22	13	7.38	3.6		
		Drum-3	91	82.93			16	8	7.45	3.8		
		Drum-4	151	71.67			14	9	7.47	4.0		
		Effluent-Total	70	86.87			8	1.7	7.51	4.0		
		Effluent-Filter	30	94.37	3	1	3	-	-			
		Efficiency (%)	94.37		83.33	61.54	96.05					

26-Oct-93

Run	Day	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
1		Influent	542		20	3.2	86	-	7.20			
29		Drum-1	943	-74.0			604	430	7.35	1.5		
		Drum-2	107	80.26			72	27	7.87	3.8		
		Drum-3	130	76.01			35	12	7.92	3.8		
		Drum-4	67	87.64			13	3.5	7.96	4.0		
		Effluent-Total	56	89.67			10	0.9	7.97	4.0		
		Effluent-Filter	29	94.65	1.8	1.4	5	-	-			
		Efficiency (%)	94.65		91.00	56.25	94.19					

28-Oct-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	1 Influent	430		17	3	72	-	6.86			
Day	31 Drum-1	876	-103.7			360	480	6.99	0.8		
	Drum-2	76	82.33			75	80	7.07	3.4		
	Drum-3	124	71.16			42	50	7.60	3.5		
	Drum-4	369	14.19			76	100	7.70	3.9		
	Effluent-Total	64	85.12			21	10	7.76	4.0		
	Effluent-Filter	28	93.49	1.4	1.1	4	-	-	-		
	Efficiency (%)	93.49		91.76	63.33	94.44					

30-Oct-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	1 Influent	553		24	3.7	82	-	7.03		362	
Day	33 Drum-1	930	-68.2			605	694	7.16	1.2		
	Drum-2	94	83.00			42	28	7.59	3.6		
	Drum-3	73	86.80			24	22	7.60	3.8		
	Drum-4	100	81.92			52	26	7.61	3.8		
	Effluent-Total	87	84.27			11	2	7.72	4.1		
	Effluent-Filter	31	94.39	4	1.3	3	-	-	-	10	
	Efficiency (%)	94.39		83.33	64.86	96.34				97.24	

01-Nov-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	2 Influent	476		18	3	76	-	6.71			
Day	35 Drum-1	766	-60.9			241	200	6.87	0.8		Change Hydraulic Loading to 50 l/m <sup>2</sup> .d
	Drum-2	515	-8.19			85	85	7.06	2.8		
	Drum-3	605	-27.10			111	150	7.18	3.2		Film at Drum 1 going to be black
	Drum-4	820	-72.3			266	200	7.28	3.6		
	Effluent-Total	190	60.08			67	80	7.30	3.8		
	Effluent-Filter	120	74.79	5	1.5	6	-	-	-		
	Efficiency (%)	74.79		72.22	50.00	92.11					

03-Nov-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	2 Influent	584		26	3.4	88	-	6.70			
Day	37 Drum-1	916	-56.8			627	550	6.74	0.5		Film at Drum 2 going to be black as Drum 1
	Drum-2	282	51.71			132	150	6.97	1.2		
	Drum-3	241	58.73			132	125	7.20	3.0		
	Drum-4	483	17.29			115	125	7.32	3.7		
	Effluent-Total	136	76.71			61	80	7.37	3.8		
	Effluent-Filter	58	90.07	6	1.5	6	-	-	-		
	Efficiency (%)	90.07		76.92	55.88	93.18					

05-Nov-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	2 Influent	678		21	3.5	92	-	7.02			
Day	39 Drum-1	1030	-51.9			660	650	7.04	0.5		
	Drum-2	600	11.50			568	350	7.51	1.2		
	Drum-3	240	64.60			136	114	7.71	2.4		
	Drum-4	420	38.05			139	120	7.76	3.8		
	Effluent-Total	153	77.43			50	40	7.83	4.0		
	Effluent-Filter	89	86.87	8	1.2	6	-	-	-		
	Efficiency (%)	86.87		61.90	65.71	93.48					

07-Nov-93

Run	Day	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
2		Influent	640		18	3.2	78	-	7.00			
41		Drum-1	936	-46.25			406	450	7.08	0.5		
		Drum-2	863	-34.84			290	200	7.49	1.2		
		Drum-3	696	-8.75			198	150	7.81	3.0		
		Drum-4	566	11.56			98	130	7.83	4.5		
		Effluent-Total	117	81.72			55	50	7.91	4.7		
		Effluent-Filter	53	91.72	4	1.4	8	-	-			
		Efficiency (%)	91.72		77.78	56.25	89.74					

09-Nov-93

Run	Day	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
2		Influent	608		18	2.8	96	-	6.90			Film at Drum 1 sloughing
43		Drum-1	1167	-91.9			742	500	7.01	0.4		
		Drum-2	530	12.83			155	180	7.75	1.3		
		Drum-3	266	56.25			189	150	7.85	2.8		
		Drum-4	365	39.97			101	150	7.87	3.9		
		Effluent-Total	190	68.75			43	80	7.99	4.0		
		Effluent-Filter	55	90.95	4	0.9	8	-	-			
		Efficiency (%)	90.95		77.78	67.86	91.67					

11-Nov-93

Run	Day	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
2		Influent	564		18	3	100	-	7.08			Film at Drum 1 & Drum 2
45		Drum-1	1046	-85.46			595	700	7.19	0.4		sloughing, reason to high
		Drum-2	927	-64.4			490	650	7.73	1.5		COD & SS
		Drum-3	849	-50.53			805	600	7.74	2.2		
		Drum-4	585	-3.72			738	500	7.77	3.4		
		Effluent-Total	464	17.73			302	400	7.88	3.5		
		Effluent-Filter	93	83.51	5	0.8	31	-	-			
		Efficiency (%)	83.51		72.22	73.33	69.00					

13-Nov-93

Run	Day	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
2		Influent	497		21	3	100	-	7.10			
47		Drum-1	980	-97.18			492	500	7.39	2.4		
		Drum-2	623	-25.35			564	360	7.66	2.8		
		Drum-3	707	-42.25			498	360	7.71	2.9		
		Drum-4	565	-13.68			558	380	7.75	4.1		
		Effluent-Total	483	2.82			398	260	7.86	4.1		
		Effluent-Filter	52	89.54	11	1.2	30	-	-			
		Efficiency (%)	89.54		47.62	60.00	70.00					

15-Nov-93

Run	Day	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
2		Influent	527		20	3.4	86	-	7.27			
49		Drum-1	760	-44.21			520	170	7.60	2.6		
		Drum-2	523	0.76			400	198	7.70	3.6		
		Drum-3	513	2.66			344	140	7.85	3.7		
		Drum-4	387	26.57			292	130	7.88	4.0		
		Effluent-Total	267	49.34			194	81	7.98	4.3		
		Effluent-Filter	46	91.27	7	1	14	-	-			
		Efficiency (%)	91.27		65.00	70.59	83.72					

17-Nov-93

Sampling Point		COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	2 Influent	527		22	3.2	84	-	7.18			
Day	51 Drum-1	929	-76.28			123	130	7.29	2.3		
	Drum-2	277	47.44			115	47	7.78	3.7		
	Drum-3	217	58.82			190	32	7.82	3.6		
	Drum-4	302	42.69			151	40	7.88	4.4		
	Effluent-Total	155	70.59			294	25	7.93	4.6		
	Effluent-Filter	31	94.12	8	1.2	14	-	-			
	Efficiency (%)	94.12		63.64	62.50	83.33					

19-Nov-93

Sampling Point		COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	2 Influent	566		22	3.4	88	-	7.19			
Day	53 Drum-1	445	21.38			482	110	7.35	1.0		
	Drum-2	361	36.22			190	66	7.79	3.9		
	Drum-3	232	59.01			135	42	7.84	4.4		
	Drum-4	206	63.60			147	43	7.89	5.0		
	Effluent-Total	255	54.95			145	41	7.93	5.2		
	Effluent-Filter	52	90.81	10	1.3	18	-	-			
	Efficiency (%)	90.81		54.55	61.76	79.55					

21-Nov-93

Sampling Point		COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	2 Influent	570		20	3	82	-	7.29			
Day	55 Drum-1	955	-67.54			934	195	7.36	1.0		
	Drum-2	488	14.39			291	160	7.61	1.0		
	Drum-3	441	22.63			226	120	7.76	3.5		
	Drum-4	364	36.14			239	115	7.77	4.3		
	Effluent-Total	287	49.65			185	80	7.81	4.4		
	Effluent-Filter	37	93.51	4	1.4	16	-	-			
	Efficiency (%)	93.51		80.00	53.33	80.49					

23-Nov-93

Sampling Point		COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	2 Influent	483		16	3	80		7.18			
Day	57 Drum-1	490	-1.45			276	60	7.42	1.6		
	Drum-2	306	36.65			144	58	7.70	3.4		
	Drum-3	253	47.62			208	48	7.77	3.6		
	Drum-4	294	39.13			215	56	7.79	4.0		
	Effluent-Total	263	45.55			169	37	7.85	4.1		
	Effluent-Filter	35	92.75	3	1	12					
	Efficiency (%)	92.75		81.25	66.67	85.00					

25-Nov-93

Sampling Point		COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	2 Influent	514		17	3.1	90		7.17		340	
Day	59 Drum-1	518	-0.78			317	152	7.36	1.4		
	Drum-2	360	29.96			342	120	7.69	3.3		
	Drum-3	335	34.82			230	110	7.75	3.4		
	Drum-4	329	35.99			292	135	7.74	4.2		
	Effluent-Total	232	54.86			186	82	7.93	4.3		
	Effluent-Filter	36	93.00	3	1.2	14				11	
	Efficiency (%)	93.00		82.35	61.29	84.44					

27-Nov-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	3 Influent	540		15	3	98		7.14			
Day	61 Drum-1	378	30.00			270	80	7.25	0.8		Change Hydraulic Loading to 75 l/m2.d  Film at Drum 1 going to be yellow (light brown)
	Drum-2	270	50.00			175	70	7.64	3.0		
	Drum-3	293	45.74			147	43	7.74	3.2		
	Drum-4	199	63.15			180	42	7.78	3.9		
	Effluent-Total	154	71.48			102	25	7.81	4.0		
	Effluent-Filter	30	94.44	4	1.6	26					
	Efficiency (%)	94.44		73.33	46.67	73.47					

29-Nov-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	3 Influent	525		18	3.1	75		7.17			
Day	63 Drum-1	863	-64.38			326	170	7.25	1.3		Film at Drum 1 going to be light brown with black spot
	Drum-2	1108	-111.0			343	280	7.58	2.7		
	Drum-3	423	19.43			251	200	7.70	3.0		
	Drum-4	535	-1.90			309	250	7.76	4.0		
	Effluent-Total	499	4.95			200	200	7.75	4.1		
	Effluent-Filter	103	80.38	5	1	19					
	Efficiency (%)	80.38		72.22	67.74	74.67					

01-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	3 Influent	585		17	3.4	78		7.18			
Day	65 Drum-1	1200	-105.1			362	240	7.26	0.7		
	Drum-2	625	-6.84			339	250	7.57	3.7		
	Drum-3	375	35.90			219	170	7.66	4.3		
	Drum-4	488	16.58			252	210	7.71	4.4		
	Effluent-Total	403	31.11			169	140	7.71	4.6		
	Effluent-Filter	68	88.38	6	1.4	22					
	Efficiency (%)	88.38		64.71	58.82	71.79					

03-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	3 Influent	471		16	3.5	76		7.20			
Day	67 Drum-1	507	-7.64			250	260	7.27	0.9		
	Drum-2	544	-15.50			413	250	7.61	2.8		
	Drum-3	635	-34.82			339	240	7.72	3.2		
	Drum-4	823	-74.73			416	240	7.74	4.0		
	Effluent-Total	433	8.07			320	145	7.76	4.0		
	Effluent-Filter	75	84.08	6	1.3	31					
	Efficiency (%)	84.08		62.50	62.86	59.21					

05-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	3 Influent	521		17	3.5	61		7.22			
Day	69 Drum-1	1074	-106.1			320	120	7.27	0.6		
	Drum-2	544	-4.41			214	160	7.6	2.3		
	Drum-3	606	-16.31			187	190	7.7	2.9		
	Drum-4	544	-4.41			248	200	7.74	3.5		
	Effluent-Total	376	27.83			192	150	7.78	3.6		
	Effluent-Filter	69	86.76	4	1.1	20					
	Efficiency (%)	86.76		76.47	68.57	67.21					



07-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	3 Influent	494		16	3.7	83		7.16			
Day	71 Drum-1	486	1.62			244	115	7.27	0.8		
	Drum-2	396	19.84			203	108	7.58	2.9		
	Drum-3	291	41.09			158	88	7.73	3.5		
	Drum-4	257	47.96			180	96	7.79	3.8		
	Effluent-Total	230	53.44			141	80	7.85	4.0		
	Effluent-Filter	46	90.69	2.8	1.9	12					
	Efficiency (%)	90.69		82.50	48.65	85.54					

09-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	3 Influent	466		20	3	93		7.20			
Day	73 Drum-1	604	-29.61			404	150	7.23	0.3		
	Drum-2	309	33.69			219	120	7.61	3.0		
	Drum-3	222	52.36			146	100	7.72	3.8		
	Drum-4	235	49.57			194	110	7.75	4.0		
	Effluent-Total	159	65.88			147	88	7.81	4.2		
	Effluent-Filter	39	91.63	3	1.2	9					
	Efficiency (%)	91.63		85.00	60.00	90.32					

11-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	3 Influent	460		17	3.3	86		7.16			D-1 is light brown
Day	75 Drum-1	416	9.57			216	110	7.22	0.3		with dark spot
	Drum-2	284	38.26			159	108	7.58	3.2		
	Drum-3	338	26.52			171	100	7.67	3.9		D-2, D-3, D-4 have
	Drum-4	293	36.30			143	100	7.78	4.3		scatter dark spot.
	Effluent-Total	219	52.39			124	88	7.82	4.3		
	Effluent-Filter	36	92.17	4	1.6	10					
	Efficiency (%)	92.17		76.47	51.52	88.37					

13-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	3 Influent	549		17	3.7	70		7.10			
Day	77 Drum-1	735	-33.88			318	70	7.20	0.5		
	Drum-2	368	32.97			208	78	7.45	3.3		
	Drum-3	390	28.96			185	64	7.58	4.0		
	Drum-4	518	5.65			204	78	7.70	4.6		
	Effluent-Total	192	65.03			90	62	7.91	4.6		
	Effluent-Filter	41	92.53	4	1.8	7					
	Efficiency (%)	92.53		76.47	51.35	90.00					

15-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	3 Influent	494		16	3.5	78		7.15		330	
Day	79 Drum-1	1051	-112.75			528	195	7.17	0.6		
	Drum-2	812	-64.4			216	158	7.41	2.9		
	Drum-3	392	20.65			183	150	7.66	3.9		
	Drum-4	360	27.13			182	155	7.69	4.0		
	Effluent-Total	240	51.42			152	115	7.71	4.0		
	Effluent-Filter	39	92.11	3	1.6	9				11.5	
	Efficiency (%)	92.11		81.25	54.29	88.46				96.52	

17-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	4 Influent	573		20	5	75		7.09			
Day	81 Drum-1	505	11.87			326	210	7.14	0.5		Change Hydraulic Loading to be 100 l/m2.d
	Drum-2	428	25.31			463	250	7.46	2.0		
	Drum-3	304	46.95			259	155	7.67	3.7		
	Drum-4	324	43.46			214	130	7.70	3.9		
	Effluent-Total	392	31.59			182	115	7.72	4.2		Film at Drum 1 thicker
	Effluent-Filter	96	83.25	5	2.5	17		7.65	3.6		
	Efficiency (%)	83.25		75.00	50.00	77.33					

19-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	4 Influent	533		17	4.4	68		7.14			
Day	83 Drum-1	1135	-112.95			252	135	7.22	0.6		Film at D-1 going to be black
	Drum-2	965	-81.05			248	170	7.4	2.2		
	Drum-3	352	33.96			150	110	7.56	3.4		
	Drum-4	733	-37.52			226	120	7.64	3.9		
	Effluent-Total	416	21.95			124	75	7.69	3.9		
	Effluent-Filter	60	88.74	4	2.5	25		7.62	3.5		
	Efficiency (%)	88.74		76.47	43.18	63.24					

21-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	4 Influent	535		20	4.5	64		7.08		355	
Day	85 Drum-1	448	16.26			250	84	7.20	0.7		Film at D-1 black D-2 going to be black
	Drum-2	716	-33.83			342	130	7.35	2.0		
	Drum-3	461	13.83			294	115	7.46	3.0		
	Drum-4	417	22.06			184	78	7.59	4.0		
	Effluent-Total	140	73.83			162	60	7.67	4.0		
	Effluent-Filter	35	93.46	3.8	2.1	28		7.59	3.8	12	
	Efficiency (%)	93.46		81.00	53.33	56.25				96.62	

23-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	4 Influent	462		19	4.3	70		7.04			
Day	87 Drum-1	763	-65.15			398	160	7.19	0.6		Film at D-1 & D-2 black
	Drum-2	802	-73.59			282	170	7.41	2.0		
	Drum-3	606	-31.17			234	125	7.61	3.7		
	Drum-4	645	-39.61			254	100	7.68	4.1		
	Effluent-Total	472	-2.16			190	82	7.75	4.2		
	Effluent-Filter	41	91.13	4	1.8	18		7.61	3.9		
	Efficiency (%)	91.13		78.95	58.14	74.29					

25-Dec-93

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	4 Influent	484		18	4.9	82		7.05		323	
Day	89 Drum-1	685	-37.40			498	145	7.19	0.4		
	Drum-2	881	-82.02			456	220	7.34	1.7		Film at Drum 1 & Drum 2 sloughing
	Drum-3	900	-85.95			464	270	7.49	2.8		
	Drum-4	987	-103.9			396	250	7.54	2.8		
	Effluent-Total	983	-103.1			276	170	7.62	3.4		
	Effluent-Filter	41	91.53	3.6	2.3	20		7.31	2.2	12	
	Efficiency (%)	91.53		80.00	53.06	75.61				96.28	

27-Dec-93

Run	Day	Sampling Point	COD	Eff. (%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
4		Influent	520		19	4.9	78		7.10			Film at Drum1 & Drum 2
91		Drum-1	695	-33.65			536	120	7.14	0.2		sloughing
		Drum-2	735	-41.35			442	145	7.32	1.2		
		Drum-3	444	14.62			252	120	7.52	3.0		
		Drum-4	409	21.35			200	81	7.59	3.7		
		Effluent-Total	218	58.08			158	70	7.63	3.7		
		Effluent-Filter	43	91.73	3.2	2.3	16		7.32	3.3		
		Efficiency (%)	91.73		83.16	53.06	79.49					

29-Dec-93

Run	Day	Sampling Point	COD	Eff. (%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
4		Influent	545		17	4.7	76		7.13		333	
93		Drum-1	680	-24.77			444	145	7.17	0.3		Film at Drum 4 is the most
		Drum-2	885	-62.39			312	180	7.32	1.5		thick
		Drum-3	537	1.47			260	150	7.52	3.0		
		Drum-4	802	-47.16			340	140	7.61	3.8		
		Effluent-Total	553	-1.47			208	98	7.70	3.6		
		Effluent-Filter	41	92.48	3.6	2.3	18		7.45	3.4	12	
		Efficiency (%)	92.48		78.82	51.06	76.32				96.40	

31-Dec-93

Run	Day	Sampling Point	COD	Eff. (%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
4		Influent	496		16	4.4	72		7.12			
95		Drum-1	592	-19.35			477	160	7.16	0.3		
		Drum-2	638	-26.63			386	140	7.33	1.4		
		Drum-3	401	19.15			243	130	7.51	3.3		
		Drum-4	438	11.69			187	110	7.60	3.7		
		Effluent-Total	365	26.41			146	76	7.68	3.6		
		Effluent-Filter	41	91.73	3.5	1.9	14		7.28	3.4		
		Efficiency (%)	91.73		78.13	56.82	80.56					

02-Jan-94

Run	Day	Sampling Point	COD	Eff. (%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
5		Influent	1137		35	7.7	160		7.15		642	
97		Drum-1	965	15.13			694	210	7.67	2.6		COD influent = 1000 mg/l
		Drum-2	1221	-7.39			864	205	7.8	3.0		Change Hydraulic Loading
		Drum-3	1024	9.94			782	180	7.85	3.2		to be 25 l/m2.d
		Drum-4	961	15.48			866	200	7.79	2.7		Organic Loading=25g/m2.
		Effluent-Total	804	29.29			846	170	7.73	2.5		
		Effluent-Filter	72	93.67	9	2.4	30		7.63	2.4	24	
		Efficiency (%)	93.67		74.29	68.83	81.25				96.26	

04-Jan-94

Run	Day	Sampling Point	COD	Eff. (%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
5		Influent	1064		35	7.4	152		7.11			
99		Drum-1	481	54.79			264	148	7.70	2.4		
		Drum-2	399	62.50			368	120	7.86	3.8		
		Drum-3	265	75.09			322	110	7.87	4.1		
		Drum-4	465	56.30			334	110	7.80	4.4		
		Effluent-Total	296	72.18			280	120	7.76	4.4		
		Effluent-Filter	71	93.33	4.7	1.3	36		7.65	3.6		
		Efficiency (%)	93.33		86.57	82.43	75.00					

06-Jan-94

Run	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
5	Influent	1111		38	8.3	164		7.20			
Day 101	Drum-1	407	63.37			314	66	7.57	2.6		
	Drum-2	436	60.76			284	52	7.81	4.2		
	Drum-3	468	57.88			260	47	7.83	4.2		
	Drum-4	475	57.25			254	45	7.92	4.4		
	Effluent-Total	412	62.92			212	43	7.89	4.2		
	Effluent-Filter	67	93.97	4.9	1.6	48		7.82	3.9		
	Efficiency (%)	93.97		87.11	80.72	70.73					

08-Jan-94

Run	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
5	Influent	1032		34	7.2	156		7.18		670	
Day 103	Drum-1	780	24.42			614	180	7.53	1.4		
	Drum-2	678	34.30			496	130	7.79	3.0		
	Drum-3	544	47.29			398	105	7.85	3.4		
	Drum-4	564	45.35			542	102	7.98	4.0		
	Effluent-Total	315	69.48			322	90	8.03	4.0		
	Effluent-Filter	67	93.51	4.2	1.6	26		7.73	3.6	24	
	Efficiency (%)	93.51		87.65	77.78	83.33				96.42	

10-Jan-94

Run	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
5	Influent	946		32	6.7	150		7.17		615	
Day 105	Drum-1	725	23.36			506	93	7.61	2.1		
	Drum-2	520	45.03			488	84	7.74	2.6		
	Drum-3	772	18.39			488	80	7.85	2.8		
	Drum-4	953	-0.74			510	74	7.96	3.9		
	Effluent-Total	697	26.32			454	84	7.99	4.0		
	Effluent-Filter	96	89.85	7.3	2.1	39		7.75	3.0	42	
	Efficiency (%)	89.85		77.19	68.66	74.00				93.17	

12-Jan-94

Run	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
5	Influent	1147		37	7.2	146		7.25			
Day 107	Drum-1	735	35.92			536	135	7.66	1.4		
	Drum-2	751	34.52			396	110	7.87	3.0		
	Drum-3	743	35.22			310	105	7.95	3.4		
	Drum-4	839	26.85			330	98	8.00	3.9		
	Effluent-Total	511	55.45			214	78	8.05	4.0		
	Effluent-Filter	65	94.33	4.3	1.2	24		7.83	3.2		
	Efficiency (%)	94.33		88.38	83.33	83.56					

14-Jan-94

Run	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
5	Influent	1045		38.5	7.6	140		7.19	1.6	695	
Day 109	Drum-1	847	18.95			532	122	7.61	1.2		
	Drum-2	759	27.37			344	80	7.82	2.8		
	Drum-3	815	22.01			392	85	7.99	3.8		
	Drum-4	791	24.31			358	86	7.98	4.0		
	Effluent-Total	366	64.98			262	64	7.98	4.2		
	Effluent-Filter	48	95.41	6.7	2.8	20		7.84	3.3	15	
	Efficiency (%)	95.41		82.60	63.16	85.71				97.84	

16-Jan-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 5 Influent	954		34	7.5	160		7.16		638	
Day 111 Drum-1	791	17.09			486	70	7.64	1.3		
Drum-2	652	31.66			252	49	7.83	2.9		
Drum-3	716	24.95			320	50	7.89	3.7		
Drum-4	538	43.61			248	48	7.91	4.1		
Effluent-Total	303	68.24			184	25	7.98	4.2		
Effluent-Filter	45	95.28	5.2	2.4	14		7.82	3.5	14	
Efficiency (%)	95.28		84.71	68.00	91.25				97.81	

18-Jan-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 5 Influent	967		36	6.8	162		7.15		665	
Day 113 Drum-1	823	14.89			454	100	7.60	1.4		
Drum-2	598	38.16			288	70	7.79	2.8		
Drum-3	626	35.26			342	72	7.88	3.6		
Drum-4	475	50.88			260	68	7.92	4.0		
Effluent-Total	321	66.80			176	40	7.97	4.1		
Effluent-Filter	46	95.24	4.8	2.3	16		7.85	3.4	14	
Efficiency (%)	95.24		86.67	66.18	90.12				97.89	

20-Jan-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 6 Influent	959		35	7.9	154		7.11			
Day 115 Drum-1	440	54.12			408	92	7.44	1.6		
Drum-2	422	56.00			336	80	7.82	3.4		
Drum-3	546	43.07			302	80	7.99	4.3		
Drum-4	703	26.69			328	90	7.98	3.9		
Effluent-Total	557	41.92			324	72	7.98	4.0		
Effluent-Filter	86	91.03	4.8	2.5	26		7.86	3.8		
Efficiency (%)	91.03		86.29	68.35	83.12					

22-Jan-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 6 Influent	984		33	7.8	156		7.14		640	
Day 117 Drum-1	472	52.03			388	220	7.50	1.6		
Drum-2	450	54.27			338	195	7.79	3.2		
Drum-3	440	55.28			278	175	7.9	4.4		
Drum-4	325	66.97			266	160	7.91	4.3		
Effluent-Total	442	55.08			276	160	7.99	4.0		
Effluent-Filter	82	91.67	5	3.2	24		7.84	3.6	14	
Efficiency (%)	91.67		84.65	58.97	84.81				97.81	

24-Jan-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 6 Influent	1127		37	7.6	168		7.28			
Day 119 Drum-1	771	31.59			434	180	7.42	0.2		
Drum-2	883	21.65			344	220	7.58	2.9		
Drum-3	591	47.56			360	235	7.75	3.4		
Drum-4	595	47.20			430	250	7.79	4		
Effluent-Total	983	12.78			322	220	7.84	4.1		
Effluent-Filter	48	95.74	3.6	2.5	20		7.79	3.6		
Efficiency (%)	95.74		90.27	67.11	88.10					

26-Jan-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 6 Influent	947		29	6.9	164	-	7.26		674	
Day 121 Drum-1	822	13.20			514	300	7.52	0.3		
Drum-2	667	29.57			414	275	7.76	2.5		
Drum-3	647	31.66			428	300	8.01	3.5		
Drum-4	739	21.96			442	295	8.02	3.8		
Effluent-Total	667	29.57			404	260	8.03	3.7		
Effluent-Filter	49	94.83	3.2	2.4	16	-	7.89	3.5	15	
Efficiency (%)	94.83		88.97	65.22	90.24					97.77

26-Jan-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 6 Influent	938		34	6.6	156	-	7.22			
Day 123 Drum-1	762	18.76			420	220	7.54	0.6		
Drum-2	804	14.29			354	200	7.69	2.6		
Drum-3	310	66.95			242	175	7.95	3.6		
Drum-4	556	40.72			278	160	7.87	3.3		
Effluent-Total	596	36.46			176	120	7.87	4.0		
Effluent-Filter	52	94.46	5	2.1	14	-	7.92	3.7		
Efficiency (%)	94.46		85.29	68.18	91.03					

30-Jan-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 6 Influent	1001		43	8.4	152	-	7.24		790	
Day 125 Drum-1	731	26.97			384	175	7.56	0.4		
Drum-2	512	48.85			244	140	7.78	2.0		
Drum-3	328	67.23			212	125	7.96	3.0		
Drum-4	620	38.06			216	120	7.92	3.2		
Effluent-Total	346	65.43			154	85	8.02	3.6		
Effluent-Filter	49	95.10	7	3.8	18	-	7.79	3.8	15	
Efficiency (%)	95.10		83.72	54.76	88.16					96.10

01-Feb-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 6 Influent	945		39	8.2	158	-	7.20			
Day 127 Drum-1	922	7.89			362	45	7.51	0.8		
Drum-2	532	46.85			222	39	7.73	2.8		
Drum-3	581	41.96			286	30	7.80	3.7		
Drum-4	310	69.03			290	23	7.66	3.6		
Effluent-Total	369	63.14			200	16	7.90	3.5		
Effluent-Filter	50	95.00	9	4.1	22	-	7.83	3.0		
Efficiency (%)	94.71		76.92	50.00	86.08					

03-Feb-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 7 Influent	1125		37	7.2	146	-	7.12			704 Film at D-1 black
Day 129 Drum-1	826	26.58			370	155	7.35	0.2		
Drum-2	1057	6.04			752	200	7.52	0.8		
Drum-3	707	37.16			716	155	7.67	1.8		
Drum-4	584	48.09			726	140	7.72	2.6		
Effluent-Total	882	21.60			572	170	7.82	2.4		
Effluent-Filter	56	95.02	5	4	28	-	7.68	2.8	17	
Efficiency (%)	95.02		86.49	44.44	80.82					97.59

05-Feb-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	7 Influent	1096		36	6.9	154	-	7.21			
Day	131 Drum-1	822	25.00			508	190	7.56	0.2		Film at D-1 & D-2 black
	Drum-2	798	27.19			552	280	7.71	0.2		
	Drum-3	862	21.35			606	300	7.82	0.3		
	Drum-4	1005	6.30			662	340	7.89	0.4		
	Effluent-Total	973	11.22			436	350	7.97	0.5		
	Effluent-Filter	326	70.26	17	2.6	94	-	7.78	0.3		
	Efficiency (%)	70.26		52.78	62.32	36.96					

07-Feb-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	7 Influent	1144		33	7.8	176	-	7.15			
Day	133 Drum-1	671	41.35			396	275	7.31	0.2		
	Drum-2	1092	4.55			360	360	7.49	0.3		
	Drum-3	639	44.14			340	410	7.6	1.2		Film at D-3 black
	Drum-4	703	38.55			354	430	7.71	1.9		
	Effluent-Total	544	52.45			250	450	7.76	2.0		
	Effluent-Filter	115	89.95	7	3.1	30	-	7.53	1.8		
	Efficiency (%)	89.95		78.79	60.26	82.95					

09-Feb-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	7 Influent	942		39	7.4	160	-	7.21		625	
Day	135 Drum-1	535	43.21			332	175	7.42	0.2		Film at D-1, D-2 & D-3 black
	Drum-2	606	35.67			552	360	7.60	0.4		
	Drum-3	645	31.53			192	170	7.77	2.0		
	Drum-4	287	69.53			256	170	7.97	3.2		
	Effluent-Total	215	77.18			168	175	7.99	3.2		
	Effluent-Filter	76	91.93	10.4	4.1	16	-	7.90	3.1	21	
	Efficiency (%)	91.93		73.33	44.59	90.00				96.64	

11-Feb-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	7 Influent	957		34	7.5	166	-	7.29			Film at D-1 & D-3 black
Day	137 Drum-1	482	49.63			220	125	7.4	0.3		
	Drum-2	490	48.80			274	185	7.6	0.6		
	Drum-3	565	40.96			240	160	7.71	2.0		
	Drum-4	310	67.61			200	155	7.94	3.1		
	Effluent-Total	251	73.77			178	180	7.97	3.2		
	Effluent-Filter	64	93.31	9	3.6	20	-	7.88	2.9		
	Efficiency (%)	93.31		73.53	52.00	87.95					

13-Feb-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run	7 Influent	1109		35	7.1	156	-	7.23	1.5	621	
Day	139 Drum-1	399	64.02			192	72	7.44	0.4		
	Drum-2	332	70.06			324	130	7.63	0.7		
	Drum-3	507	54.28			224	140	7.74	2.1		
	Drum-4	346	68.80			196	125	7.95	3.3		
	Effluent-Total	291	73.76			148	120	7.98	3.3		
	Effluent-Filter	59	94.68	8	3.7	14	-	7.90	2.8	17	
	Efficiency (%)	94.68		77.14	47.89	91.03				97.26	

15-Feb-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 7 Influent	1045		36	6.9	162	-	7.27			
Day 141 Drum-1	633	39.43			336	140	7.46	0.3		
Drum-2	566	45.84			412	300	7.64	0.8		
Drum-3	484	53.68			380	250	7.65	2.0		
Drum-4	535	48.80			364	250	7.97	3.1		
Effluent-Total	515	50.72			288	280	8.03	3.2		
Effluent-Filter	62	94.07	8.4	3	22	-	7.94	2.9		
Efficiency (%)	94.07		76.67	56.52	86.42					

17-Feb-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 7 Influent	1140		33	7.2	170	-	7.10		616	
Day 143 Drum-1	582	48.95			436	175	7.30	0.2		
Drum-2	550	51.75			472	270	7.56	1.0		
Drum-3	391	65.70			372	280	7.72	1.9		
Drum-4	519	54.47			292	255	7.85	2.6		
Effluent-Total	606	46.84			308	260	7.91	2.8		
Effluent-Filter	61	94.65	5.9	2.7	18	-	7.77	2.7	17	
Efficiency (%)	94.65		82.12	62.50	89.41				97.24	

19-Feb-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 8 Influent	1106		33.5	6.9	172	-	7.22			
Day 145 Drum-1	868	21.52			716	350	7.38	0.3		
Drum-2	752	32.01			668	250	7.50	0.3		
Drum-3	748	32.37			924	400	7.46	0.4		
Drum-4	1075	2.80			904	448	7.52	0.6		
Effluent-Total	277	74.95			780	280	7.82	0.8		
Effluent-Filter	201	81.83	13	3	76	-	7.51	0.7		
Efficiency (%)	81.83		61.19	56.52	55.81					

21-Feb-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 8 Influent	1045		35	7.3	152	-	7.19		735	
Day 147 Drum-1	1136	-8.71			600	80	7.40	0.3		
Drum-2	1274	-21.91			728	130	7.46	0.5		
Drum-3	1154	-10.43			528	120	7.49	0.8		
Drum-4	816	21.91			464	125	7.65	2.0		
Effluent-Total	613	41.34			356	110	7.80	2.2		
Effluent-Filter	209	80.00	13.4	3.2	62	-	7.60	1.8	85	
Efficiency (%)	80.00		61.71	56.16	59.21				88.44	

23-Feb-94

Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 8 Influent	951		36	7.2	170	-	7.01			
Day 149 Drum-1	593	37.64			220	58	7.22	0.3		
Drum-2	448	52.89			384	85	7.46	0.4		
Drum-3	625	34.28			256	110	7.71	1.6		
Drum-4	468	50.79			292	130	7.80	2.2		
Effluent-Total	368	61.30			248	170	7.66	3.6		
Effluent-Filter	100	89.48	7	3.4	16	-	7.69	2.8		
Efficiency (%)	89.48		80.56	52.78	90.59					



25-Feb-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 8	Influent	963		46	7.8	158	-	7.10			
Day 151	Drum-1	1361	-41.33			336	120	7.26	0.2		
	Drum-2	1616	-67.81			424	200	7.46	0.3		
	Drum-3	720	25.23			356	150	7.69	0.6		
	Drum-4	489	49.22			316	175	7.66	1.7		
	Effluent-Total	299	68.95			296	210	7.68	2.9		
	Effluent-Filter	86	91.07	12	3.4	28	-	7.65	1.8		
	Efficiency (%)	91.07		73.91	56.41	82.28					

27-Feb-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 8	Influent	939		34	7.5	180	-	7.14		639	
Day 153	Drum-1	474	49.52			244	80	7.27	0.2		
	Drum-2	494	47.39			330	86	7.51	0.3		
	Drum-3	448	52.29			240	90	7.67	0.8		
	Drum-4	438	53.35			264	120	7.80	2.0		
	Effluent-Total	273	70.93			212	95	7.91	3.1		
	Effluent-Filter	68	92.76	9.5	3	28	-	7.68	2.1	34	
	Efficiency (%)	92.76		72.06	60.00	84.44				94.68	

01-Mar-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 8	Influent	962		35.5	9.3	182	-	7.16			
Day 155	Drum-1	456	52.60			320	120	7.29	0.4		
	Drum-2	509	47.09			304	150	7.54	0.6		
	Drum-3	503	47.71			280	165	7.60	1.3		
	Drum-4	341	64.55			288	225	7.72	2.2		
	Effluent-Total	334	65.28			240	250	7.78	3.0		
	Effluent-Filter	71	92.62	6.3	4.5	26	-	7.65	2.8		
	Efficiency (%)	92.62		82.25	51.61	85.71					

03-Mar-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 8	Influent	955		35	9.8	202	-	7.17			
Day 157	Drum-1	594	37.80			368	56	7.28	0.7		
	Drum-2	708	25.86			372	120	7.46	1.0		
	Drum-3	704	26.28			480	125	7.68	1.4		
	Drum-4	417	56.34			476	160	7.79	1.8		
	Effluent-Total	354	62.93			308	120	7.87	2.4		
	Effluent-Filter	74	92.25	5.9	4.6	26	-	7.67	1.6		
	Efficiency (%)	92.25		83.14	53.06	87.13					

05-Mar-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 8	Influent	944		36	9.8	210	-	7.15		657	
Day 159	Drum-1	535	43.33			340	95	7.28	0.4		
	Drum-2	433	54.13			288	130	7.56	0.8		
	Drum-3	429	54.56			292	150	7.63	2.1		
	Drum-4	460	51.27			332	200	7.70	3.0		
	Effluent-Total	339	64.09			260	180	7.83	3.2		
	Effluent-Filter	73	92.27	10	5.2	20	-	7.75	2.8	21	
	Efficiency (%)	92.27		72.22	46.94	90.48				96.80	

07-Mar-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 9	Influent	330		11.8	3.3	52		7.29			Film at D-1 & D-3 black
Day 161	Drum-1	304	7.88			196	46	7.52	1.3		and begin to slough
	Drum-2	288	12.73			176	56	7.67	2.2		
	Drum-3	210	36.36			136	52	7.66	3.0		Film at D-4 looks pale
	Drum-4	224	32.12			112	48	7.89	3.8		
	Effluent-Total	144	56.36			90	25	7.96	3.8		
	Effluent-Filter	63	80.91	5.8	1.6	18		7.85	3.3		
	Efficiency (%)	80.91		50.85	51.52	65.38					

09-Mar-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 9	Influent	363		10.5	3	56		7.23		220	Film at D-1 & D-2 brown
Day 163	Drum-1	267	20.94			182	54	7.42	1.2		with black
	Drum-2	120	66.94			84	45	7.59	2.0		
	Drum-3	169	53.44			70	28	7.91	3.2		Film at D-3 & D-4 are
	Drum-4	102	71.90			118	30	7.9	4.1		light brown
	Effluent-Total	94	74.10			50	8.5	7.95	4.3		
	Effluent-Filter	43	88.15	4.8	1.5	12		7.91	4.0	11	
	Efficiency (%)	88.15		54.29	50.00	78.57				95.00	

11-Mar-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 9	Influent	359		13	1.9	48		7.25			Film at D-1 & D-2 are
Day 165	Drum-1	277	22.84			212	80	7.41	1.1		brown with black spot
	Drum-2	193	46.24			112	80	7.56	2.1		
	Drum-3	313	12.81			246	110	7.7	3.0		Film at D-3 & D-4 are
	Drum-4	124	65.46			146	114	7.82	3.9		light brown
	Effluent-Total	114	68.25			94	60	7.92	4.0		
	Effluent-Filter	39	89.14	3.7	1.3	8		7.86	3.2		
	Efficiency (%)	89.14		71.54	31.58	83.33					

13-Mar-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 9	Influent	338		11.2	2.5	60		7.26		210	Film at D-1 is brown
Day 167	Drum-1	277	18.05			200	55	7.49	1.8		with black
	Drum-2	322	4.73			116	48	7.58	2.8		
	Drum-3	191	43.49			114	32	7.70	3.5		Film at D-2, D-3 & D-4
	Drum-4	206	38.46			76	22	7.88	4.1		are brown
	Effluent-Total	122	63.91			86	26	7.96	4.2		
	Effluent-Filter	38	88.76	4.9	1.1	8		7.91	4.0	11.5	
	Efficiency (%)	88.76		56.25	56.00	86.67				94.52	

15-Mar-94

	Sampling Point	COD	Eff.(%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
Run 9	Influent	358		12	2.9	54		7.24		218	Film at D-1 is dark
Day 169	Drum-1	320	10.61			234	29	7.43	1.7		brown with black
	Drum-2	292	18.44			202	28	7.60	2.9		Film at D-2, D-3 & D-4
	Drum-3	320	10.61			174	23	7.78	3.7		are brown
	Drum-4	267	25.42			170	25	7.89	4.1		
	Effluent-Total	190	46.93			154	26	7.95	4.0		
	Effluent-Filter	42	88.27	5	1.1	16		7.89		12	
	Efficiency (%)	88.27		58.33	62.07	70.37				94.50	

17-Mar-94

Run	Day	Sampling Point	COD	Eff. (%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
9		Influent	263		11.6	3	58		7.30			
171		Drum-1	305	-15.97			206	60	7.55	1.8		
		Drum-2	300	-14.07			154	58	7.69	3.2		
		Drum-3	245	6.84			130	42	7.63	3.9		
		Drum-4	247	6.08			116	48	7.92	4.1		
		Effluent-Total	205	22.05			108	40	7.98	4.2		
		Effluent-Filter	43	83.65	2.3	1.1	14		7.93	4.1		
		Efficiency (%)	83.65		80.17	63.33	75.66					


19-Mar-94

Run	Day	Sampling Point	COD	Eff. (%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
9		Influent	259		12	2.8	50		7.23		190	Film at D-1 is dark
173		Drum-1	340	5.03			188	60	7.45	1.9		brown with black
		Drum-2	363	-1.40			132	58	7.63	3.4		Film at D-2, D-3 & D-4
		Drum-3	219	38.83			100	34	7.80	4.2		are brown
		Drum-4	158	55.87			62	31	7.88	4.4		
		Effluent-Total	192	46.37			78	33	8.04	4.4		
		Effluent-Filter	42	88.27	3.5	1	10		8.00	4.2	12	
		Efficiency (%)	83.78		70.83	64.29	80.00				93.68	

21-Mar-94

Run	Day	Sampling Point	COD	Eff. (%)	TKN	T-PO4	SS	SV30	pH	DO	BOD5	Remark
9		Influent	293		10.4	2.9	52		7.20			
175		Drum-1	317	-20.53			192	60	7.43	2.0		
		Drum-2	189	28.14			124	50	7.68	3.6		
		Drum-3	203	22.81			116	38	7.78	4.2		
		Drum-4	193	26.62			140	35	7.85	4.2		
		Effluent-Total	162	38.40			66	28	7.96	4.3		
		Effluent-Filter	40	84.79	2.4	0.9	6		7.92			
		Efficiency (%)	86.35		76.92	68.97	88.46					

ศูนย์วิทยทรัพยากร  
จุฬาลงกรณ์มหาวิทยาลัย



ภาคผนวก ข ผลการทดลองแยกตามตัวแปร

ศูนย์วิทยทรัพยากร  
จุฬาลงกรณ์มหาวิทยาลัย

pH									
	Date	Day Influent	Stage				4 Effluent	Remark	
			1	2	3				
Run 1	28-Sep-93	1	7.25	7.32	7.44	7.61	7.62	7.80	Org.Loading=12.5g/m2.c
	30-Sep-93	3	7.31	7.38	7.49	7.65	7.66	7.83	
	02-Oct-93	5	7.35	7.46	7.72	8.15	7.82	8.05	
	04-Oct-93	7	7.37	7.46	7.83	7.93	7.93	8.00	
	06-Oct-93	9	7.36	7.43	7.84	7.92	7.95	7.96	
	08-Oct-93	11	7.32	7.43	7.78	7.84	7.88	7.92	
	10-Oct-93	13	7.41	7.56	7.88	7.81	7.87	8.00	
	12-Oct-93	15	7.30	7.45	7.80	7.92	7.96	7.96	
	14-Oct-93	17	7.10	7.34	7.60	7.78	7.80	7.97	
	16-Oct-93	19	7.09	7.28	7.51	7.70	7.79	7.82	
	18-Oct-93	21	6.94	7.00	7.22	7.64	7.74	7.77	
	20-Oct-93	23	6.98	7.04	7.38	7.52	7.57	7.65	
	22-Oct-93	25	7.24	7.32	7.50	7.59	7.62	7.68	
	24-Oct-93	27	6.91	6.97	7.38	7.45	7.47	7.51	
	26-Oct-93	29	7.20	7.35	7.87	7.92	7.96	7.97	
	28-Oct-93	31	6.86	6.99	7.07	7.60	7.70	7.76	
	30-Oct-93	33	7.03	7.16	7.59	7.60	7.61	7.72	
Avg			7.18	7.29	7.58	7.74	7.76	7.85	
Run 2	01-Nov-93	35	6.71	6.87	7.06	7.18	7.28	7.30	Org.Loading=25g/m2.d
	03-Nov-93	37	6.70	6.74	6.97	7.20	7.32	7.37	
	05-Nov-93	39	7.02	7.04	7.51	7.71	7.76	7.83	
	07-Nov-93	41	7.00	7.08	7.49	7.81	7.83	7.91	
	09-Nov-93	43	6.90	7.01	7.75	7.85	7.87	7.99	
	11-Nov-93	45	7.08	7.19	7.73	7.74	7.77	7.88	
	13-Nov-93	47	7.10	7.39	7.66	7.71	7.75	7.86	
	15-Nov-93	49	7.27	7.60	7.70	7.85	7.88	7.98	
	17-Nov-93	51	7.18	7.29	7.78	7.82	7.88	7.93	
	19-Nov-93	53	7.19	7.35	7.79	7.84	7.89	7.93	
	21-Nov-93	55	7.29	7.36	7.61	7.76	7.77	7.81	
	23-Nov-93	57	7.18	7.42	7.70	7.77	7.79	7.85	
	25-Nov-93	59	7.17	7.36	7.69	7.75	7.74	7.93	
Avg			7.06	7.21	7.57	7.69	7.73	7.81	
Run 3	27-Nov-93	61	7.14	7.25	7.64	7.74	7.78	7.81	Org.Loading=37.5g/m2.c
	29-Nov-93	63	7.17	7.25	7.58	7.70	7.76	7.75	
	01-Dec-93	65	7.18	7.26	7.57	7.66	7.71	7.71	
	03-Dec-93	67	7.20	7.27	7.61	7.72	7.74	7.76	
	05-Dec-93	69	7.22	7.27	7.60	7.70	7.74	7.78	
	07-Dec-93	71	7.18	7.27	7.58	7.73	7.79	7.85	
	09-Dec-93	73	7.20	7.23	7.61	7.72	7.75	7.81	
	11-Dec-93	75	7.16	7.22	7.58	7.67	7.78	7.82	
	13-Dec-93	77	7.10	7.20	7.45	7.58	7.70	7.91	
	15-Dec-93	79	7.15	7.17	7.41	7.66	7.69	7.71	
Avg			7.17	7.23	7.56	7.68	7.74	7.79	
Run 4	17-Dec-93	81	7.09	7.14	7.46	7.67	7.70	7.72	Org.Loading=50g/m2.d
	19-Dec-93	83	7.14	7.22	7.40	7.56	7.64	7.69	
	21-Dec-93	85	7.08	7.20	7.35	7.46	7.59	7.67	
	23-Dec-93	87	7.04	7.19	7.41	7.61	7.68	7.75	
	25-Dec-93	89	7.05	7.19	7.34	7.49	7.54	7.62	
	27-Dec-93	91	7.10	7.14	7.32	7.52	7.59	7.63	
	29-Dec-93	93	7.13	7.17	7.32	7.52	7.61	7.70	
	31-Dec-93	95	7.12	7.16	7.33	7.51	7.60	7.68	
Avg			7.09	7.18	7.37	7.54	7.62	7.68	

## pH

	Date	Day	Influent	Stage				4 Effluent	Remark
				1	2	3			
Run 5	02-Jan-94	97	7.15	7.67	7.80	7.85	7.79	7.73	Org.Loading=25g/m2.d
	04-Jan-94	99	7.11	7.70	7.86	7.87	7.80	7.76	
	06-Jan-94	101	7.20	7.57	7.81	7.83	7.92	7.89	
	08-Jan-94	103	7.18	7.53	7.79	7.85	7.98	8.03	
	10-Jan-94	105	7.17	7.61	7.74	7.85	7.96	7.99	
	12-Jan-94	107	7.25	7.66	7.87	7.95	8.00	8.05	
	14-Jan-94	109	7.19	7.61	7.82	7.99	7.98	7.98	
	16-Jan-94	111	7.18	7.64	7.83	7.89	7.91	7.98	
	18-Jan-94	113	7.15	7.60	7.79	7.88	7.92	7.97	
Avg			7.18	7.62	7.81	7.88	7.92	7.93	
Run 6	20-Jan-94	115	7.11	7.44	7.82	7.99	7.98	7.98	Org.Loading=50g/m2.d
	22-Jan-94	117	7.14	7.50	7.79	7.90	7.91	7.99	
	24-Jan-94	119	7.28	7.42	7.58	7.75	7.79	7.84	
	26-Jan-94	121	7.26	7.52	7.76	8.01	8.02	8.03	
	28-Jan-94	123	7.22	7.54	7.69	7.95	7.87	7.87	
	30-Jan-94	125	7.24	7.56	7.78	7.96	7.92	8.02	
	01-Feb-94	127	7.20	7.51	7.73	7.80	7.86	7.90	
Avg			7.21	7.50	7.74	7.91	7.91	7.95	
Run 7	03-Feb-94	129	7.12	7.35	7.52	7.67	7.72	7.82	Org.Loading=75g/m2.d
	05-Feb-94	131	7.21	7.56	7.71	7.82	7.89	7.97	
	07-Feb-94	133	7.15	7.31	7.49	7.60	7.71	7.76	
	09-Feb-94	135	7.21	7.42	7.60	7.77	7.97	7.99	
	11-Feb-94	137	7.29	7.40	7.60	7.71	7.94	7.97	
	13-Feb-94	139	7.23	7.44	7.63	7.74	7.95	7.98	
	15-Feb-94	141	7.27	7.46	7.64	7.85	7.97	8.03	
	17-Feb-94	143	7.10	7.30	7.56	7.72	7.85	7.91	
Avg			7.20	7.41	7.59	7.74	7.88	7.93	
Run 8	19-Feb-94	145	7.22	7.38	7.50	7.46	7.52	7.82	Org.Loading=100g/m2.d
	21-Feb-94	147	7.19	7.40	7.46	7.49	7.65	7.80	
	23-Feb-94	149	7.01	7.22	7.46	7.71	7.80	7.86	
	25-Feb-94	151	7.10	7.26	7.46	7.69	7.66	7.68	
	27-Feb-94	153	7.14	7.27	7.75	7.67	7.80	7.91	
	01-Mar-94	155	7.16	7.29	7.54	7.60	7.72	7.78	
	03-Mar-94	157	7.17	7.28	7.46	7.68	7.79	7.87	
	05-Mar-94	159	7.15	7.28	7.56	7.63	7.70	7.83	
Avg			7.14	7.30	7.52	7.62	7.71	7.82	
Run 9	07-Mar-94	161	7.29	7.52	7.67	7.66	7.89	7.96	
	09-Mar-94	163	7.23	7.42	7.59	7.91	7.90	7.95	Org.Loading=30g/m2.d
	11-Mar-94	165	7.25	7.41	7.75	7.70	7.82	7.92	
	13-Mar-94	167	7.26	7.49	7.58	7.70	7.88	7.96	
	15-Mar-94	169	7.24	7.43	7.60	7.78	7.89	7.95	
	17-Mar-94	171	7.30	7.55	7.69	7.83	7.92	7.98	
	19-Mar-94	173	7.23	7.45	7.63	7.80	7.88	8.04	
	21-Mar-94	175	7.20	7.43	7.68	7.78	7.85	7.96	
Avg			7.24	7.45	7.65	7.79	7.88	7.97	

## COD

	Date	Day	Influent	Drum Stage				Effluent	
				1	2	3	4	Total	Settled
Run 1	28-Sep-93	1	519	459	361	332	258	207	107
	30-Sep-93	3	517	468	306	285	237	186	66
	02-Oct-93	5	468	463	272	255	229	128	36
	04-Oct-93	7	609	616	340	333	330	161	50
	06-Oct-93	9	468	242	248	246	166	71	25
	08-Oct-93	11	440	290	287	279	215	70	29
	10-Oct-93	13	481	445	281	274	197	72	32
	12-Oct-93	15	440	276	256	127	218	65	48
	14-Oct-93	17	452	210	339	221	309	56	41
	16-Oct-93	19	415	455	250	230	392	51	30
	18-Oct-93	21	571	925	420	167	104	49	24
	20-Oct-93	23	448	889	203	117	191	43	21
	22-Oct-93	25	451	818	148	102	124	52	25
	24-Oct-93	27	533	496	23	91	151	70	30
26-Oct-93	29	542	943	107	130	67	56	29	
28-Oct-93	31	430	876	76	124	369	64	28	
30-Oct-93	33	553	930	94	73	100	87	31	
Avg			490	577	236	199	215	88	38
Run 2	01-Nov-93	35	476	766	515	605	820	190	120
	03-Nov-93	37	584	918	282	241	483	136	58
	05-Nov-93	39	678	1030	800	240	420	153	89
	07-Nov-93	41	640	936	863	696	566	117	53
	09-Nov-93	43	608	1167	530	266	365	190	55
	11-Nov-93	45	564	1046	927	849	585	464	93
	13-Nov-93	47	497	980	623	707	565	483	52
	15-Nov-93	49	527	760	523	513	387	267	46
	17-Nov-93	51	527	929	277	217	302	155	31
	19-Nov-93	53	566	445	361	232	206	255	52
	21-Nov-93	55	570	955	488	441	364	287	37
	23-Nov-93	57	483	490	306	253	294	263	35
	25-Nov-93	59	514	518	360	335	329	232	36
	Avg			556	641	512	430	437	246
Run 3	27-Nov-93	61	540	378	270	293	199	154	30
	29-Nov-93	63	525	863	1108	423	535	499	103
	01-Dec-93	65	585	1200	625	375	488	403	68
	03-Dec-93	67	471	507	544	635	823	433	75
	05-Dec-93	69	521	1074	544	606	544	376	69
	07-Dec-93	71	494	486	396	291	257	230	46
	09-Dec-93	73	466	604	309	222	235	159	39
	11-Dec-93	75	460	416	284	338	293	219	36
	13-Dec-93	77	549	735	368	390	518	192	41
	15-Dec-93	79	494	1051	812	392	360	240	39
	Avg			511	731	526	397	425	291
Run 4	17-Dec-93	81	573	505	428	304	324	392	96
	19-Dec-93	83	533	1135	965	352	733	416	60
	21-Dec-93	85	535	448	716	461	417	140	35
	23-Dec-93	87	462	763	802	606	645	472	41
	25-Dec-93	89	484	665	881	900	987	983	41
	27-Dec-93	91	520	695	735	444	409	218	43
	29-Dec-93	93	545	680	885	537	802	553	41
	31-Dec-93	95	496	592	638	401	438	365	41
Avg			519	685	756	501	594	442	50

## COD

	Date	Day	Influent	Drum Stage				Effluent	
				1	2	3	4	Total	Settled
Run 5	02-Jan-94	97	1137	965	1221	1024	961	804	72
	04-Jan-94	99	1064	481	399	265	465	296	71
	06-Jan-94	101	1111	407	436	468	475	412	67
	08-Jan-94	103	1032	780	678	544	564	315	67
	10-Jan-94	105	946	725	520	772	953	697	96
	12-Jan-94	107	1147	735	751	743	839	511	65
	14-Jan-94	109	1045	847	759	815	791	366	48
	16-Jan-94	111	954	791	652	716	538	303	45
	18-Jan-94	113	967	823	598	626	475	321	46
Avg			1045	728	668	664	673	447	64
Run 6	20-Jan-94	115	959	440	422	546	703	557	86
	22-Jan-94	117	984	472	450	440	325	442	82
	24-Jan-94	119	1127	771	883	591	595	983	48
	26-Jan-94	121	947	822	667	647	739	667	49
	28-Jan-94	123	938	762	804	310	556	596	52
	30-Jan-94	125	1001	731	512	328	620	346	49
	01-Feb-94	127	945	922	532	581	310	369	50
	Avg			986	703	610	492	550	566
Run 7	03-Feb-94	129	1125	826	1057	707	584	882	56
	05-Feb-94	131	1096	822	798	862	1005	973	326
	07-Feb-94	133	1144	671	1092	639	703	544	115
	09-Feb-94	135	942	535	606	645	287	215	76
	11-Feb-94	137	957	482	490	565	310	251	64
	13-Feb-94	139	1109	399	332	507	346	291	59
	15-Feb-94	141	1045	633	566	484	535	515	62
	17-Feb-94	143	1140	582	550	391	519	606	61
Avg			1070	619	686	600	536	535	102
Run 8	19-Feb-94	145	1106	868	752	748	1075	277	201
	21-Feb-94	147	1045	1136	1274	1154	816	613	209
	23-Feb-94	149	951	593	448	625	468	368	100
	25-Feb-94	151	963	1361	1616	720	489	299	86
	27-Feb-94	153	939	474	494	448	438	273	68
	01-Mar-94	155	962	456	509	503	341	334	71
	03-Mar-94	157	955	594	708	704	417	354	74
	05-Mar-94	159	944	535	433	429	460	339	73
Avg			983	752	779	666	563	357	110
Run 9	07-Mar-94	161	330	304	288	210	224	144	63
	09-Mar-94	163	363	287	120	169	102	94	43
	11-Mar-94	165	359	277	193	313	124	114	39
	13-Mar-94	167	338	277	322	191	208	122	38
	15-Mar-94	169	358	320	292	320	267	190	42
	17-Mar-94	171	263	305	300	245	247	205	43
	19-Mar-94	173	259	340	363	219	158	192	42
	21-Mar-94	175	293	317	189	203	193	162	40
Avg			320	303	258	234	190	153	44



#### 5.4.2 ซีไอดีและประสิทธิภาพการกำจัด

##### 5.4.2.1 ค่าซีไอดีของน้ำเสียที่เข้าสู่ระบบ

การหาค่าซีไอดีของน้ำเสียที่เข้าสู่ระบบและน้ำเสียในระบบไบโอดรัมแต่ละตอนได้วิเคราะห์ออกมาในรูปของซีไอดีรวม ส่วนค่าซีไอดีของน้ำเสียออกจากระบบนั้นได้วิเคราะห์ทั้งในรูปของซีไอดีรวม และซีไอดีของน้ำใสหลังจากทิ้งให้ตะกอนจมตัวแล้ว ค่าซีไอดีของน้ำเสียที่เข้าสู่ระบบได้ทำการเตรียมที่ความเข้มข้น 500 มก./ลิตร , 1,000 มก./ลิตร และ 300 มก./ลิตร สำหรับการทดลองชุดที่ 1, 2 และ 3 ตามลำดับ อย่างไรก็ตาม การเตรียมน้ำเสียสังเคราะห์ซึ่งทำขึ้นในห้องปฏิบัติการอาจมีความคลาดเคลื่อนจากค่าที่กำหนดไว้ประมาณ  $\pm 20\%$  รูปที่ 5.15 เป็นการแสดงค่าซีไอดีที่ทำการป้อนกันเข้าสู่ระบบไบโอดรัมของการทดลองแต่ละชุด

##### 5.4.2.2 ผลการทดลอง

การทดลองของระบบพบว่าทุกการทดลอง ค่าซีไอดีที่ตำแหน่งต่างๆ ของการเก็บตัวอย่างน้ำเสียมักค่าเปลี่ยนแปลงโดยมีแนวโน้มที่ค่าเฉลี่ยซีไอดีในไบโอดรัมตอนหลังๆ และในน้ำทิ้งจะลดต่ำลงดังแสดงในรูปที่ 5.16 อย่างไรก็ตามเมื่อค่าไฮดรอลิกไหลคงเพิ่มสูงขึ้น รูปแบบแนวโน้มของค่าซีไอดีอาจเปลี่ยนแปลงไปบ้างเนื่องจากอิทธิพลของสารแขวนลอยที่เกิดจากการหลุดลอกตัวของฟิล์มชีว

รูปที่ 5.16 แสดงให้เห็นว่าการทดลองทั้ง 3 ชุด มีแนวโน้มของการเปลี่ยนแปลงซีไอดีที่ลดลงในแต่ละจุดเก็บตัวอย่างน้ำเสียตามเส้นทางท่ไหลของน้ำจนถึงจุดน้ำเสียออกจากระบบ ข้อแตกต่างที่ค่อนข้างชัดเจนของการทดลองทั้ง 3 ชุด ได้แก่ ในการทดลองที่ 1 ค่าซีไอดีของน้ำเสียของตอนที่ 1 เพิ่มสูงขึ้นในขณะที่การทดลองชุดอื่นค่าซีไอดีลดลง สาเหตุที่เกิดขึ้นเนื่องมาจากตอนที่ 1 เป็นตอนที่สารอาหารเริ่มถูกป้อนเข้าสู่ระบบ ดังนั้นจึงเป็นตอนที่มีความเข้มข้นของสารอาหารสูงที่สุด การใช้สารอาหารของจุลชีพจึงสูงที่สุดตามไปด้วย ฟิล์มชีวของจุลชีพในตอนนี้เกิดขึ้นในปริมาณมาก การเก็บตัวอย่างน้ำเสียในการทดลองช่วงแรกไม่มีเทคนิคที่ดีพอเนื่องจากยังไม่มีความรู้ความชำนาญจึงมีส่วนของฟิล์มชีวติดมาด้วย ประกอบกับไบโอดรัมที่ใช้ในระบบมีขนาดเล็ก ความจุน้อย หากทำการคูดน้ำเสียออกมามากจะทำให้มีส่วนของฟิล์มปะปนมาด้วยจึงเป็นสาเหตุให้ค่าซีไอดีที่วิเคราะห์ในตอนที่ 1 มีค่าสูง อีกสาเหตุหนึ่งซึ่งน่าจะเป็นผลให้ค่าซีไอดีในช่วงแรกสูงเนื่องจากช่วงแรกเกิดจุลชีพแบบเส้นใยขึ้นในตอนแรกของไบโอดรัม เมื่อทำการเก็บตัวอย่างน้ำเสียจึงมีจุลชีพติดออกมาด้วยเป็นผลให้ค่าซีไอดีสูงขึ้นดังกล่าว ในการ

## SS

	Date	Day	Influent	Drum Stage				Effluent	
				1	2	3	4	Total	Settled
Run 1	28-Sep-93	1	74	82.6	65	85	73	62	6
	30-Sep-93	3	88	170	125	120	105	98	12
	02-Oct-93	5	82	348	246	242	200	184	16
	04-Oct-93	7	86	362	233	248	228	64	11
	06-Oct-93	9	80	259	214	214	180	50	7
	08-Oct-93	11	76	238	148	134	135	24	6
	10-Oct-93	13	84	198	176	180	156	24	10
	12-Oct-93	15	78	284	201	196	154	49	9
	14-Oct-93	17	80	168	210	174	150	43	7
	16-Oct-93	19	74	236	131	99	97	19	4
	18-Oct-93	21	90	775	184	99	98	15	7
	20-Oct-93	23	70	510	296	129	113	18	5
	22-Oct-93	25	82	642	48	33	32	26	5
	24-Oct-93	27	76	151	22	16	14	8	3
26-Oct-93	29	86	604	72	35	13	10	5	
28-Oct-93	31	72	360	75	42	76	21	4	
30-Oct-93	33	82	605	42	24	52	11	3	
Avg			80	353	146	122	110	43	7
Run 2	01-Nov-93	35	76	241	85	111	266	67	6
	03-Nov-93	37	88	627	132	132	115	61	6
	05-Nov-93	39	92	660	568	136	139	50	6
	07-Nov-93	41	78	406	290	198	98	55	8
	09-Nov-93	43	96	742	155	189	101	43	8
	11-Nov-93	45	100	595	490	805	738	302	31
	13-Nov-93	47	100	492	564	498	558	398	30
	15-Nov-93	49	86	520	400	344	292	194	14
	17-Nov-93	51	84	123	115	190	151	294	14
	19-Nov-93	53	88	482	190	135	147	145	18
	21-Nov-93	55	82	934	291	226	239	185	16
	23-Nov-93	57	80	276	144	208	215	169	12
25-Nov-93	59	90	317	342	230	292	186	14	
Avg			88	493	290	262	258	165	14
Run 3	27-Nov-93	61	98	270	175	147	180	102	26
	29-Nov-93	63	75	328	343	251	309	200	19
	01-Dec-93	65	78	362	339	219	252	169	22
	03-Dec-93	67	76	250	413	339	416	320	31
	05-Dec-93	69	61	320	214	187	248	192	20
	07-Dec-93	71	83	244	203	158	180	141	12
	09-Dec-93	73	93	404	219	146	194	147	9
	11-Dec-93	75	86	216	159	171	143	124	15
	13-Dec-93	77	70	318	208	185	204	90	7
	15-Dec-93	79	78	528	216	183	182	152	9
Avg			80	324	249	199	231	164	17
Run 4	17-Dec-93	81	75	326	463	259	214	182	17
	19-Dec-93	83	68	252	248	150	226	124	25
	21-Dec-93	85	64	250	342	294	184	162	28
	23-Dec-93	87	70	398	262	234	254	190	18
	25-Dec-93	89	82	498	456	464	396	276	20
	27-Dec-93	91	78	536	442	252	200	158	16
	29-Dec-93	93	80	444	312	260	340	208	18
	31-Dec-93	95	72	477	386	243	187	146	14
Avg			74	398	366	270	250	181	20

## SS

	Date	Day	Influent	Drum Stage				Effluent	
				1	2	3	4	Total	Settled
Run 5	02-Jan-94	97	160	694	864	782	866	846	30
	04-Jan-94	99	152	264	368	322	334	280	38
	06-Jan-94	101	164	314	284	260	254	212	48
	08-Jan-94	103	156	614	496	398	542	322	26
	10-Jan-94	105	150	506	488	488	510	454	39
	12-Jan-94	107	146	536	396	310	330	214	24
	14-Jan-94	109	140	532	344	392	358	262	20
	16-Jan-94	111	60	486	252	320	248	184	14
	18-Jan-94	113	162	454	288	342	260	176	16
Avg			143	489	420	402	411	328	28
Run 6	20-Jan-94	115	154	408	336	302	328	324	26
	22-Jan-94	117	158	388	338	278	266	276	24
	24-Jan-94	119	168	434	344	360	430	322	20
	26-Jan-94	121	164	514	414	428	442	404	16
	28-Jan-94	123	156	420	354	242	278	176	14
	30-Jan-94	125	152	384	244	212	216	154	18
	01-Feb-94	127	158	362	222	286	290	200	22
Avg			159	416	322	301	321	265	20
Run 7	03-Feb-94	129	146	370	752	716	726	572	28
	05-Feb-94	131	154	508	552	606	662	436	94
	07-Feb-94	133	176	396	360	340	354	250	30
	09-Feb-94	135	160	332	552	192	256	168	16
	11-Feb-94	137	166	220	274	240	200	178	20
	13-Feb-94	139	156	192	324	224	196	148	14
	15-Feb-94	141	162	336	412	380	364	288	22
	17-Feb-94	143	170	436	472	372	292	308	18
Avg			161	349	462	384	381	294	30
Run 8	19-Feb-94	145	172	716	868	924	904	780	76
	21-Feb-94	147	152	600	728	528	464	356	62
	23-Feb-94	149	170	220	384	256	292	248	16
	25-Feb-94	151	158	336	424	356	316	296	28
	27-Feb-94	153	180	244	330	240	264	212	28
	01-Mar-94	155	182	320	304	280	288	240	26
	03-Mar-94	157	202	368	372	480	476	308	26
	05-Mar-94	159	210	340	288	292	332	260	20
Avg			178	393	462	420	417	338	35
Run 9	07-Mar-94	161	52	196	176	136	112	90	18
	09-Mar-94	163	56	182	84	70	118	50	12
	11-Mar-94	165	48	212	112	246	146	94	8
	13-Mar-94	167	60	200	116	114	76	86	8
	15-Mar-94	169	54	234	202	174	170	154	16
	17-Mar-94	171	58	206	154	130	116	108	14
	19-Mar-94	173	50	188	132	100	82	78	10
	21-Mar-94	175	52	192	124	116	140	86	6
Avg			54	202	132	136	121	94	11

## DO

	Organic Loading	Date	Day	Stage				Effluent Total		
				1	2	3	4			
Run 1	12.5 g COD/m <sup>2</sup> .d	26-Sep-93	1	2.0	2.7	3.6	4.0	3.9		
		30-Sep-93	3	2.2	3.0	3.8	4.1	4.0		
		02-Oct-93	5	4.1	4.2	4.4	4.6	4.5		
		04-Oct-93	7	3.2	4.3	4.6	4.6	4.2		
		06-Oct-93	9	2.9	4.2	4.2	4.2	4.2		
		08-Oct-93	11	3.4	4.3	4.6	4.9	4.8		
		10-Oct-93	13	3.8	4.9	5.0	5.2	5.2		
		12-Oct-93	15	3.7	4.6	4.6	4.8	4.8		
		14-Oct-93	17	2.5	4.2	5.0	5.1	5.0		
		16-Oct-93	19	2.5	4.2	4.6	5.2	5.2		
		18-Oct-93	21	2.5	4.0	4.8	4.9	4.9		
		20-Oct-93	23	1.6	3.3	3.7	4.2	4.2		
		22-Oct-93	25	1.8	3.6	4.2	4.6	4.6		
		24-Oct-93	27	1.3	3.6	3.8	4.0	4.0		
		26-Oct-93	29	1.5	3.8	3.8	4.0	4.0		
28-Oct-93	31	0.8	3.4	3.5	3.9	4.0				
30-Oct-93	33	1.2	3.6	3.8	3.8	4.1				
Avg				2.4	3.9	4.2	4.5	4.4		
Run 2	25 g COD/m <sup>2</sup> .d	01-Nov-93	35	0.8	2.8	3.2	3.6	3.8		
		03-Nov-93	37	0.5	1.2	3.0	3.7	3.8		
		05-Nov-93	39	0.5	1.2	2.4	3.8	4.0		
		07-Nov-93	41	0.5	1.2	3.0	4.5	4.7		
		09-Nov-93	43	0.4	1.3	2.8	3.9	4.0		
		11-Nov-93	45	0.4	1.5	2.2	3.4	3.5		
		13-Nov-93	47	2.4	2.8	2.9	4.1	4.1		
		15-Nov-93	49	2.6	3.6	3.7	4.0	4.3		
		17-Nov-93	51	2.3	3.7	3.6	4.4	4.6		
		19-Nov-93	53	1.0	3.9	4.4	5.0	5.2		
		21-Nov-93	55	1.0	1.0	3.5	4.3	4.4		
		23-Nov-93	57	1.6	3.4	3.6	4.0	4.1		
		25-Nov-93	59	1.4	3.3	3.4	4.2	4.3		
		Avg				1.2	2.4	3.2	4.1	4.2
		Run 3	37.5 g COD/m <sup>2</sup> .d	27-Nov-93	61	0.8	3.0	3.2	3.9	4.0
29-Nov-93	63			1.3	2.7	3.0	4.0	4.1		
01-Dec-93	65			0.7	3.7	4.3	4.4	4.6		
03-Dec-93	67			0.9	2.8	3.2	4.0	4.0		
05-Dec-93	69			0.6	2.3	2.9	3.5	3.6		
07-Dec-93	71			0.8	2.9	3.5	3.8	4.0		
09-Dec-93	73			0.3	3.0	3.8	4.0	4.2		
11-Dec-93	75			0.3	3.2	3.9	4.3	4.3		
13-Dec-93	77			0.5	3.3	4.0	4.6	4.6		
15-Dec-93	79			0.6	2.9	3.9	4.0	4.0		
Avg				0.7	3.0	3.6	4.1	4.1		
Run 4	50 g COD/m <sup>2</sup> .d	17-Dec-93	81	0.5	2.0	3.7	3.9	4.2		
		19-Dec-93	83	0.6	2.2	3.4	3.9	3.9		
		21-Dec-93	85	0.7	2.0	3.0	4.0	4.0		
		23-Dec-93	87	0.6	2.0	3.7	4.1	4.2		
		25-Dec-93	89	0.4	1.7	2.8	2.8	3.4		
		27-Dec-93	91	0.2	1.2	3.0	3.7	3.7		
		29-Dec-93	93	0.3	1.5	3.0	3.8	3.8		
		31-Dec-93	95	1.1	1.8	3.3	3.7	3.8		
Avg				0.6	1.8	3.2	3.7	3.9		

DO								
	Organic Loading	Date	Day	Stage				Effluent
				1	2	3	4	Total
Run 5	25 g COD/m <sup>2</sup> .d	02-Jan-94	97	2.6	3.0	3.2	2.7	2.5
		04-Jan-94	99	2.4	3.8	4.1	4.4	4.4
		06-Jan-94	101	2.6	4.2	4.2	4.4	4.2
		08-Jan-94	103	1.4	3.0	3.4	4.0	4.0
		10-Jan-94	105	2.1	2.6	2.8	3.3	3.3
		12-Jan-94	107	1.4	3.0	3.4	3.9	4.0
		14-Jan-94	109	1.2	2.8	3.6	4	4.2
		16-Jan-94	111	1.3	2.9	3.7	4.1	4.2
		18-Jan-94	113	1.4	2.8	3.6	4.0	4.1
Avg			1.8	3.1	3.6	3.9	3.9	
Run 6	50 g COD/m <sup>2</sup> .d	20-Jan-94	115	1.6	3.4	4.3	3.9	4.0
		22-Jan-94	117	1.6	3.2	4.4	4.3	4.0
		24-Jan-94	119	0.2	2.9	3.4	4.0	4.1
		26-Jan-94	121	0.3	2.5	3.5	3.8	3.7
		28-Jan-94	123	0.6	2.6	3.6	3.3	4.0
		30-Jan-94	125	0.4	2.0	3.0	3.2	3.6
		01-Feb-94	127	0.8	2.8	3.7	3.6	3.5
		Avg			0.8	2.8	3.7	3.7
Run 7	75 g COD/m <sup>2</sup> .d	03-Feb-94	129	0.2	0.8	1.8	2.6	2.4
		05-Feb-94	131	0.2	0.2	0.3	0.4	0.5
		07-Feb-94	133	0.2	0.3	1.2	1.9	2.0
		09-Feb-94	135	0.2	0.4	2.0	3.2	3.2
		11-Feb-94	137	0.3	0.6	2.0	3.1	3.2
		13-Feb-94	139	0.4	0.7	2.1	3.3	3.3
		15-Feb-94	141	0.3	0.8	2.0	3.1	3.2
		17-Feb-94	143	0.2	1.0	1.9	2.6	2.8
Avg			0.0	0.6	1.7	2.5	2.6	
Run 8	100 g COD/m <sup>2</sup> .d	19-Feb-94	145	0.3	0.3	0.4	0.6	0.8
		21-Feb-94	147	0.3	0.5	0.8	2.0	2.2
		23-Feb-94	149	0.3	0.4	1.6	2.2	3.6
		25-Feb-94	151	0.2	0.3	0.6	1.7	2.9
		27-Feb-94	153	0.2	0.3	0.8	2.0	3.1
		01-Mar-94	155	0.4	0.6	1.3	2.2	3.0
		03-Mar-94	157	0.7	1.0	1.4	1.8	2.4
		05-Mar-94	159	0.4	0.8	2.1	3.0	3.2
Avg			0.4	0.5	1.1	1.9	2.7	
Run 9	30 g COD/m <sup>2</sup> .d	07-Mar-94	161	1.3	2.2	3.0	3.8	3.8
		09-Mar-94	163	1.2	2.0	3.2	4.1	4.3
		11-Mar-94	165	1.1	2.1	3.0	3.9	4.0
		13-Mar-94	167	1.8	2.8	3.5	4.1	4.2
		15-Mar-94	169	1.7	2.9	3.7	4.1	4.0
		17-Mar-94	171	1.8	3.2	3.9	4.1	4.2
		19-Mar-94	173	1.9	3.4	4.2	4.4	4.4
		21-Mar-94	175	2.0	3.6	4.2	4.2	4.3
Avg			1.6	2.8	3.6	4.1	4.2	

## SV 30

	Date	Day	Stage 1	Stage 2	Stage 3	Stage 4	Effluent
Run 1	28-Sep-93	1	11.5	11	29	16	ND
	30-Sep-93	3	23.5	17.5	30.5	47.4	5
	02-Oct-93	5	30	19	28	34	3
	04-Oct-93	7	35	22	26	21	10.5
	06-Oct-93	9	63	30.5	30.5	30	15
	08-Oct-93	11	68	18	15	16	4
	10-Oct-93	13	41	12	13	11	4
	12-Oct-93	15	118	85	60	61	35
	14-Oct-93	17	102	84	53	70	31
	16-Oct-93	19	140	88	50	58	20
	18-Oct-93	21	250	81	25	26	3
	20-Oct-93	23	648	113	35	48	5
	22-Oct-93	25	660	29	20	10	2
	24-Oct-93	27	230	13	8	9	1.7
	26-Oct-93	29	430	27	12	3.5	0.9
	28-Oct-93	31	480	80	50	100	10
	30-Oct-93	33	694	28	22	26	2
Avg			238	45	30	35	9
Run 2	01-Nov-93	35	200	85	150	200	80
	03-Nov-93	37	550	150	125	125	80
	05-Nov-93	39	650	350	114	120	40
	07-Nov-93	41	450	200	150	130	50
	09-Nov-93	43	500	180	150	150	80
	11-Nov-93	45	700	650	600	500	400
	13-Nov-93	47	500	360	360	380	260
	15-Nov-93	49	170	198	140	130	81
	17-Nov-93	51	130	47	32	40	25
	19-Nov-93	53	110	66	42	43	41
	21-Nov-93	55	195	160	120	115	80
	23-Nov-93	57	60	58	48	56	37
	25-Nov-93	59	152	120	110	135	82
Avg			336	202	165	163	103
Run 3	27-Nov-93	61	80	70	43	42	25
	29-Nov-93	63	170	280	200	250	200
	01-Dec-93	65	240	250	170	210	140
	03-Dec-93	67	260	250	240	240	145
	05-Dec-93	69	120	160	190	200	150
	07-Dec-93	71	115	108	88	96	80
	09-Dec-93	73	150	120	100	110	88
	11-Dec-93	75	110	108	100	100	88
	13-Dec-93	77	70	78	64	78	62
	15-Dec-93	79	195	158	150	155	115
Avg			151	158	135	148	109
Run 4	17-Dec-93	81	107	141	119	121	96
	19-Dec-93	83	135	170	110	120	75
	21-Dec-93	85	84	130	115	78	60
	23-Dec-93	87	160	170	125	100	82
	25-Dec-93	89	145	220	270	250	170
	27-Dec-93	91	120	145	120	81	70
	29-Dec-93	93	145	180	150	140	98
	31-Dec-93	95	160	140	130	110	76
Avg			132	162	142	125	91

## SV 30

	Date	Day	Stage 1	Stage 2	Stage 3	Stage 4	Effluent
Run 5	02-Jan-94	97	210	205	180	200	170
	04-Jan-94	99	148	120	110	110	120
	06-Jan-94	101	66	52	47	45	43
	08-Jan-94	103	180	130	105	102	90
	10-Jan-94	105	93	84	80	74	84
	12-Jan-94	107	135	110	105	98	78
	14-Jan-94	109	122	80	85	86	64
	16-Jan-94	111	70	49	50	48	25
	18-Jan-94	113	100	70	72	68	40
Avg			125	100	93	92	79
Run 6	20-Jan-94	115	92	80	80	90	72
	22-Jan-94	117	220	195	175	160	160
	24-Jan-94	119	180	220	235	250	220
	26-Jan-94	121	300	275	300	295	260
	28-Jan-94	123	220	200	175	160	120
	30-Jan-94	125	175	140	125	120	85
	01-Feb-94	127	45	39	30	23	16
	Avg			176	164	160	157
Run 7	03-Feb-94	129	155	200	155	140	170
	05-Feb-94	131	190	280	300	340	350
	07-Feb-94	133	275	360	410	430	450
	09-Feb-94	135	175	360	170	170	175
	11-Feb-94	137	125	185	160	155	180
	13-Feb-94	139	72	130	140	125	120
	15-Feb-94	141	140	300	250	250	280
	17-Feb-94	143	175	270	280	255	260
	Avg			163	261	233	233
Run 8	19-Feb-94	145	350	250	400	448	280
	21-Feb-94	147	80	130	120	125	110
	23-Feb-94	149	58	85	110	130	170
	25-Feb-94	151	120	200	150	175	210
	27-Feb-94	153	80	86	90	120	95
	01-Mar-94	155	120	150	185	225	250
	03-Mar-94	157	56	120	125	160	120
	05-Mar-94	159	105	155	200	300	210
	Avg			121	147	173	210
Run 9	07-Mar-94	161	95	130	150	200	180
	09-Mar-94	163	46	56	52	48	25
	11-Mar-94	165	54	45	28	30	8.5
	13-Mar-94	167	80	80	110	114	60
	15-Mar-94	169	55	48	32	22	26
	17-Mar-94	171	29	28	23	25	26
	19-Mar-94	173	60	58	34	31	33
	21-Mar-94	175	60	50	38	35	28
	Avg			60	62	58	63

## TKN

	Date	Day	Influent	Effluent Settled	%Remove Settled
Run 1	28-Sep-93	1	16	3.92	76
	30-Sep-93	3	15	2	87
	02-Oct-93	5	14	3	79
	04-Oct-93	7	18	3.4	81
	06-Oct-93	9	17	5	71
	08-Oct-93	11	16	5	69
	10-Oct-93	13	16	2	88
	12-Oct-93	15	15	2	87
	14-Oct-93	17	17	1.4	92
	16-Oct-93	19	16	3	81
	18-Oct-93	21	29	2	93
	20-Oct-93	23	16	1	94
	22-Oct-93	25	18	3	83
	24-Oct-93	27	18	3	83
26-Oct-93	29	20	1.8	91	
28-Oct-93	31	17	1.4	92	
30-Oct-93	33	24	4	83	
Avg			18	3	84
Run 2	01-Nov-93	35	18	5	72
	03-Nov-93	37	26	6	77
	05-Nov-93	39	21	8	62
	07-Nov-93	41	18	4	78
	09-Nov-93	43	18	4	78
	11-Nov-93	45	18	5	72
	13-Nov-93	47	21	11	48
	15-Nov-93	49	20	7	65
	17-Nov-93	51	22	8	64
	19-Nov-93	53	22	10	55
	21-Nov-93	55	20	4	80
	23-Nov-93	57	16	3	81
	25-Nov-93	59	17	3	82
	Avg			20	6
Run 3	27-Nov-93	61	15	4	73
	29-Nov-93	63	18	5	72
	01-Dec-93	65	17	6	65
	03-Dec-93	67	16	6	63
	05-Dec-93	69	17	4	76
	07-Dec-93	71	16	2.8	83
	09-Dec-93	73	20	3	85
	11-Dec-93	75	17	4	76
	13-Dec-93	77	17	4	76
	15-Dec-93	79	16	3	81
	Avg			17	4
Run 4	17-Dec-93	81	20	4	80
	19-Dec-93	83	17	4	76
	21-Dec-93	85	20	3.8	81
	23-Dec-93	87	19	4	79
	25-Dec-93	89	18	3.6	80
	27-Dec-93	91	19	4.2	78
	29-Dec-93	93	17	3.6	79
	31-Dec-93	95	16	3.5	78
Avg			18	4	79



## TKN

	Date	Day	Influent	Effluent Settled	%Remove Settled
Run 5	02-Jan-94	97	35	9	74
	04-Jan-94	99	35	4.7	87
	06-Jan-94	101	38	4.9	87
	08-Jan-94	103	34	4.2	88
	10-Jan-94	105	32	7.3	77
	12-Jan-94	107	37	4.3	88
	14-Jan-94	109	38.5	6.7	83
	16-Jan-94	111	34	5.2	85
	18-Jan-94	113	36	4.8	87
Avg			36	6	84
Run 6	20-Jan-94	115	35	4.8	86
	22-Jan-94	117	33	5	85
	24-Jan-94	119	37	3.6	90
	26-Jan-94	121	29	3.2	89
	28-Jan-94	123	34	5	85
	30-Jan-94	125	43	7	84
	01-Feb-94	127	39	9	77
	03-Feb-94	129	37	5	86
Avg			36	5	85
Run 7	05-Feb-94	131	36	17	53
	07-Feb-94	133	33	7	79
	09-Feb-94	135	39	10.4	73
	11-Feb-94	137	34	9	74
	13-Feb-94	139	35	8	77
	15-Feb-94	141	36	8.4	77
	17-Feb-94	143	33	5.9	82
Avg			35	9	73
Run 8	19-Feb-94	145	33.5	13	61
	21-Feb-94	147	35	13.4	62
	23-Feb-94	149	36	7	81
	25-Feb-94	151	46	12	74
	27-Feb-94	153	34	9.5	72
	01-Mar-94	155	35.5	6.3	82
	03-Mar-94	157	35	5.9	83
	05-Mar-94	159	36	10	72
Avg			36	10	73
Run 9	07-Mar-94	161	11.8	5.8	51
	09-Mar-94	163	10.5	4.8	54
	11-Mar-94	165	13	3.7	72
	13-Mar-94	167	11.2	4.9	56
	15-Mar-94	169	12	5	58
	17-Mar-94	171	11.6	2.3	80
	19-Mar-94	173	12	3.5	71
	21-Mar-94	175	10.4	2.4	77
Avg			12	4	65

## PO4

	Date	Day	Influent	Effluent Settled	%Remove Settled
Run 1	28-Sep-93	1	3.2	2.8	13
	30-Sep-93	3	3.6	2.2	39
	02-Oct-93	5	3.7	2	46
	04-Oct-93	7	3.8	2	47
	06-Oct-93	9	3.4	0.8	76
	08-Oct-93	11	2.8	1	64
	10-Oct-93	13	3	0.9	70
	12-Oct-93	15	3	0.5	83
	14-Oct-93	17	3	0.8	73
	16-Oct-93	19	2.1	0.8	62
	18-Oct-93	21	2.8	0.8	71
	20-Oct-93	23	3.2	1.9	41
	22-Oct-93	25	3	1.4	53
	24-Oct-93	27	2.6	1	62
26-Oct-93	29	3.2	1.4	56	
28-Oct-93	31	3	1.1	63	
30-Oct-93	33	3.7	1.3	65	
Avg			3.1	1.3	58.0
Run 2	01-Nov-93	35	3	1.5	50
	03-Nov-93	37	3.4	1.5	58
	05-Nov-93	39	3.5	1.2	66
	07-Nov-93	41	3.2	1.4	56
	09-Nov-93	43	2.8	0.9	68
	11-Nov-93	45	3	0.8	73
	13-Nov-93	47	2	1.2	40
	15-Nov-93	49	3.4	1	71
	17-Nov-93	51	3.2	1.2	63
	19-Nov-93	53	3.4	1.3	62
	21-Nov-93	55	3	1.4	53
	23-Nov-93	57	3	1	67
	25-Nov-93	59	3.1	1.2	61
	Avg			3.1	1.2
Run 3	27-Nov-93	61	3	1.6	47
	29-Nov-93	63	3.1	1	68
	01-Dec-93	65	3.4	1.4	59
	03-Dec-93	67	3.5	1.3	63
	05-Dec-93	69	2.5	1.1	56
	07-Dec-93	71	3.7	1.9	49
	09-Dec-93	73	3	1.2	60
	11-Dec-93	75	3.3	1.8	52
	13-Dec-93	77	3.7	1.8	51
	15-Dec-93	79	3.5	1.6	54
	Avg			3.3	1.5
Run 4	17-Dec-93	81	5	2.5	50
	19-Dec-93	83	4.4	2.5	43
	21-Dec-93	85	4.5	2.1	53
	23-Dec-93	87	4.3	1.8	58
	25-Dec-93	89	4.9	2.3	53
	27-Dec-93	91	4.9	2.3	53
	29-Dec-93	93	4.7	2.3	51
	31-Dec-93	95	4.4	1.9	57
Avg			4.6	2.2	52.3

## PO4

	Date	Day	Influent	Effluent Settled	%Remove Settled
Run 5	02-Jan-94	97	7.7	2.4	69
	04-Jan-94	99	7.4	1.3	82
	06-Jan-94	101	8.3	1.6	81
	08-Jan-94	103	7.2	1.6	78
	10-Jan-94	105	6.7	2.1	69
	12-Jan-94	107	7.2	1.2	83
	14-Jan-94	109	7.6	2.8	63
	16-Jan-94	111	7.5	2.4	68
	18-Jan-94	113	6.8	2.3	66
Avg			7.4	2.0	73.2
Run 6	20-Jan-94	115	7.9	2.5	68
	22-Jan-94	117	7.8	3.2	59
	24-Jan-94	119	7.6	2.5	67
	26-Jan-94	121	6.9	2.4	65
	28-Jan-94	123	6.6	2.1	68
	30-Jan-94	125	8.4	3.8	55
	01-Feb-94	127	8.2	4.1	50
Avg			7.6	2.9	61.8
Run 7	03-Feb-94	129	7.2	4	44
	05-Feb-94	131	6.9	2.6	62
	07-Feb-94	133	7.8	3.1	60
	09-Feb-94	135	7.4	4.1	45
	11-Feb-94	137	7.5	3.6	52
	13-Feb-94	139	7.1	3.7	48
	15-Feb-94	141	6.9	3	57
	17-Feb-94	143	7.2	2.7	63
Avg			7.3	3.4	53.8
Run 8	19-Feb-94	145	6.9	3	57
	21-Feb-94	147	7.3	3.2	56
	23-Feb-94	149	7.2	3.4	53
	25-Feb-94	151	7.8	3.4	56
	27-Feb-94	153	7.5	3	60
	01-Mar-94	155	9.3	4.5	52
	03-Mar-94	157	9.8	4.6	53
	05-Mar-94	159	9.8	5.2	47
Avg			8.2	3.8	54.2
Run 9	07-Mar-94	161	3.3	1.6	52
	09-Mar-94	163	3	1.5	50
	11-Mar-94	165	1.9	1.3	52
	13-Mar-94	167	2.5	1.1	56
	15-Mar-94	169	2.9	1.1	62
	17-Mar-94	171	3	1.1	63
	19-Mar-94	173	2.8	1.0	64
	21-Mar-94	175	2.9	0.9	69
Avg			2.8	1.2	55.9



### ประวัติผู้วิจัย

นายธีรวัตร โสมวดี สำเร็จการศึกษาปริญญาตรี วิศวกรรมศาสตรบัณฑิต สาขา  
เครื่องกล จากมหาวิทยาลัยเกษตรศาสตร์ เข้ามาศึกษาต่อในหลักสูตรปริญญาโทบัณฑิต สาขา  
วิศวกรรมสิ่งแวดล้อมที่จุฬาลงกรณ์มหาวิทยาลัย ปีการศึกษา 2532 ปัจจุบันเป็นวิศวกรประจำที่  
บริษัท ACT CONSULTANTS CO.,LTD.



ศูนย์วิทยทรัพยากร  
จุฬาลงกรณ์มหาวิทยาลัย