

## References

1. The National Energy Policy Organization. **Handbook of the energy conservation plan, direction, criteria, condition, and the priority of the payment of the energy conservation fund.** Bangkok,1996. p1.
2. The Department of the Energy Development and Promotion, **Energy Conservation Fund. Brochure of the energy conservation in state building project: High Efficiency Electrical Equipment for Energy Conservation of Government.** 1998, (Mimeographed) pp1-2.
3. The Department of Energy Development and Promotion and The Federation of Thailand Industries. **Contract to be an Implementing Agency for the Energy Audit Management, Contract for Hiring the Energy Audit Consultant, Contract to be an Implementing Agency for the Energy Conservation Improvement, Contract for hiring Energy Conservation Contractor.** 1996,1997,1998, and 1999, (Mimeographed) Appendix pp 1-4
4. Energy Conservation Center of Thailand. **Executive Summary Report,** 1996, 1997, 1998, and 1999. (Mimeographed), pp 2-1 - 2-3.
5. Energy Conservation Improvement in State Building. **Progress report of the Energy Audit Management, Energy Audit, Management of the Energy Conservation Improvement, Controlling of the Energy Conservation Improvement, Implement of the Energy Conservation Improvement.** 1996, 1997, 1998, and 1999, (Mimeographed).
6. Harold Kerzern. **Project Management, A System to Planing, Scheduling and Controlling,** 5<sup>th</sup>. New York: Van Nostrand Reinhold Company, 1995.

7. The Department of Energy Development and Promotion. **Term of Reference of the Energy Audit in Sftate Building** (Mimeographed) pp1-6.
8. The Bureau of Energy Regulation and Conservation, The Department of Energy Develoment, Misnistry of Science Technology and Environment, **Energy Conservation in Building B11**. 4 th edition, 1998. pp 33-37.
9. Technic of the Energy Management in Building . **Energy Journal** 8<sup>th</sup> Year Vol. 42 July to September, 1991 pp 50-52
10. Energy Conservation Service Branch, Bureau of Energy Regulation and Conservation, The Department of Energy Development and Promotion. **The Regulation of Controled Building Follow through the Act of the Energy Conservation 1995**, 1995 , pp 5-6
11. A Technical Assistance Program of the Office of Energy , Bureau for Science and Technology , United States Agency for Internatinal Development. **A Report of the Energy Conservation Services Program, Industrial Energy Auditing Manual**. Washington, DC: Hagler, Bailly and Company, August 1984. pp1-1 – 1-3.
12. AEEMTRC: ASEAB-EC Energy Management Training and Research Center. **Energy Efficiency and Conservation in ASEAN. Country Report, Indonesia**. 1997. p20.
13. The Bureau of Energy Regulation and Conservation, The Department of Energy Develoment, Misnistry of Science Technology and Environment **Handbook of the Energy Conservation for Controlled Building as the act of the Energy Conservation 1992 A5**. p 8.

14. Azmi Kaya, Ph.D.,P.E. Department of Mechanical Engineering, The University of Akron , Akron, Ohio, USA and E.G. Bailey Training Center Staff. **Energy Management in Industry**. Bailey Controls Company, 1989. p1.1.1
15. Department of Energy Development and Promotion (DEDP), Ministry of Science, Technology and Environment (MOSTE). **Energy Conservation Promotion Act B.E.2535**. Bureau of Energy Regulation and Conservation, 1992. p9.
16. Songsri Pitiyarat, Monta Puawilai, Sorachai Pisanbut, Suchada Kiranan. **Principle of Statistic**. Bangkok: Chulalongkorn Ukniversity, 1994. pp 271-274.
17. Energy Conservation Service Branch, Bureau of Energy Regulation and Conservation, **The Department of Energy Development and Promotion. Regulation as the Act of Energy Conservation 1992 (about the principle method and timeline for the controlled building owner for target and plan setting) A4**. 5<sup>th</sup> edition, 1993 pp 13-15.
18. Document sheet from module. **Competitive Design Management**. Engineering Business Management Course. Chulalongkom University/University of Warwick, 1997.
19. Mayuree Srichai. **Fundamental Statistics**. 2th edition. VJ Printing, 2536. p 52.
20. Rawewan Shinatrakul. **Educational Research Methodology** 2th edition Pappim Press. Bangkok, 1995.

APPENDIX  
STANDARD FORMAT OF THE ENERGY AUDIT FOR ENERGY  
CONSERVATION IN STATE BUILDING

**Mistake number 1**

Use Factor F from this table (Factor F is used for calculating the operating, variation, interest, profit, and VAT)

Advance Payment		15.00%		Retention		5.00%		Interest		10.00%	
Budget	Period (months)	Operating	Retention	Interest	Profit	VAT	Factor F				
less than	500000.00	3	10.00%	0.50%	2.98%	18.50%	1.31975	7.96%	1.42480		
	1000000.00	3	8.00%	0.50%	2.90%	17.50%	1.28900	7.96%	1.39160		
	3000000.00	3	6.50%	0.50%	2.83%	16.00%	1.25825	7.96%	1.35841		
	5000000.00	4	6.50%	0.50%	2.67%	13.00%	1.22667	7.96%	1.32431		
	8000000.00	5	6.50%	0.50%	2.56%	12.00%	1.21558	7.96%	1.31234		
	10000000.00	6	6.50%	0.50%	2.45%	11.00%	1.20450	7.96%	1.30038		
	20000000.00	9	6.00%	0.50%	2.18%	10.50%	1.19175	7.96%	1.28661		
	50000000.00	12	6.00%	0.50%	1.90%	9.50%	1.17900	7.96%	1.27285		
	100000000.00	15	6.00%	0.50%	1.63%	8.50%	1.16625	7.96%	1.25908		
	200000000.00	16	5.00%	0.50%	1.52%	8.50%	1.15517	7.96%	1.24712		
	400000000.00	17	5.00%	0.50%	1.41%	7.50%	1.14408	7.96%	1.23515		
	600000000.00	18	4.30%	0.50%	1.31%	7.50%	1.13608	7.96%	1.22651		
	1000000000.00	20	4.00%	0.50%	1.12%	7.00%	1.12621	7.96%	1.21585		
	1500000000.00	22	3.50%	0.50%	0.93%	6.50%	1.11429	7.96%	1.20299		
	2000000000.00	24	3.50%	0.50%	0.76%	6.50%	1.11263	7.96%	1.20119		
	2500000000.00	26	3.50%	0.50%	0.60%	6.50%	1.11096	7.96%	1.19939		
	3000000000.00	30	3.50%	0.50%	0.26%	6.50%	1.10763	7.96%	1.19579		
	4000000000.00	36	3.50%	0.50%	-0.24%	6.50%	1.10263	7.96%	1.19039		
	5000000000.00	36	3.40%	0.50%	-0.24%	6.50%	1.10160	7.96%	1.18929		
more than	5000000000.00	36	3.30%	0.50%	-0.24%	6.50%	1.10058	7.96%	1.18818		

If the budget is between the step in the table, use the interpolation to calculate the Factor F

Budget	2000000.00	base	Factor F	1.28661
Budget	10000000.00	base	Factor F	1.30038
Budget	---	base	Factor F	$1.30038 - [(\text{---} - 1000000) / (2000000 - 1000000)] \times (1.30038 - 1.28661)$

**Mistake number 2**

Lifetime of Equipment for calculating EIRR	Year
1 Reflector Luminary	10
2 Reflector	10
3 Compact Fluorescent (10,000 hours)	
7-8 hours/day operating	5*
10-12 hours/day operating	4*
16 hours/day operating	3*
24 hours/day operating	2*
4 Fluorescent (8,000 hours)	
7-8 hours/day operating	4*
10-12 hours/day operating	3*
16 hours/day operating	2*
24 hours/day operating	1*
5 Electronics ballast	20
6 Low wall loss ballast	20
7 Air conditioner	15
8 Electronics thermostat	5
9 Insulation/Ceramic coating	15
10 Film	15

\*mark \* means the operating hour 250 days/year

**Mistake number 4**

Lumen per lamp of the high efficiency type using in the EasyLux Program (program for calculating the illumination in the room)

18 watt	warm white	1350 lumen
32 watt	warm white	3350 lumen
18 watt	white	1350 lumen
36 watt	white	3350 lumen
18 watt	day light	1300 lumen
36 watt	day light	3250 lumen

**Mistake number 3**

Capacity selection for the new air conditioner (use only the high-light block only)

Capacity as the specification	U (Btu/hr)				T (Btu/hr)				A (Btu/hr)			
	Size	Btu	Watt	EER	Size	Btu	Watt	EER	Size	Btu	Watt	EER
	12000-13000	12000	12095	1129	10.71	13000	12963	1163	11.14	12500	12857	1171
16100-16600	18000	17913	1550	11.55					16000	17048	1591	10.71
18000-20000	20000	21417	1886	11.35	19000	18734	1733	10.8	18000	18236	1713	10.64
24000-25000	25000	26061	2359	11.04	25000	23958	2093	11.44	25000	24997	2278	10.97
28000	30000	30034	2975	10.1	30000	28712	2622	10.95	28000	27264	2830	9.63
32000-34000									32000	30944	3220	9.61
36000-38000	36000	34471	3500	9.85	36000	34400	3535	9.73	36000	35119	3562	9.86
42000-44000	42000	43345	4495	9.64					42000	41145	4263	9.65
	48000	45734	4627	9.88	48000	48778	4952	9.85	52000	50400	5250	9.6
									56000	55792	5640	9.89
					60000	56905	5747	9.9	60000	58752	6120	9.6
									62000	60808	6186	9.83

<p><b>Mistake number 5</b></p> <p>The revised report should use the blue cover and the white hoop for report and send to ECCT 2 times</p> <ol style="list-style-type: none"> <li>1. First time, send 2 draft reports (after approved by ECCT)</li> <li>2. Second time, send 4 final reports (after approved by DEDP)</li> </ol> <p>The sequence in each section</p> <p>Section 1 The Energy Audit Report</p> <ol style="list-style-type: none"> <li>1. Fly page and Cover</li> <li>2. Letter of acceptance by building owner</li> <li>3. Letter of approval by auditor</li> <li>4. Letter of approval by ECCT</li> <li>5. Technical data</li> <li>6. Bill of quantity (BOQ)</li> <li>7. Abstract</li> <li>8. Contents</li> <li>9. Chapter 1-5</li> <li>10. Appendix A data from auditing</li> <li>11. Appendix B OTTV and RTTV calculation</li> <li>12. Appendix C data for controlled building</li> <li>13. Appendix D data for government or state-owned building</li> </ol> <p>Section 2</p> <p>(Use the same cover as the energy audit report but use the "Appendix E and F" instead of "Energy Audit Report")</p> <ol style="list-style-type: none"> <li>14. Appendix E iso-lux calculation</li> <li>15. Appendix F input of OTTV and RTTV</li> </ol> <p>Section 3</p> <p>Energy Conservation Improvement Drawing (use A3 paper only and combine the before and after improvement (Excluding the A3 Drawing of the lux calculation))</p> <p>Section 4</p> <p>Diskett 2 sets ( 1 set means energy audit report, energy conservation improvement drawing, and appendix)</p>	<p>LOGO</p> <p>Bureau of Energy Conservation and Regulation Department of Energy Development and Promotion Ministry of Science, Technology, and Environment</p>
<p><b>Mistake number 6</b></p> <p>The sequence of the Energy Conservation Improvement Drawing</p> <ol style="list-style-type: none"> <li>1. Cover and fly page</li> <li>2. Index sheet of the existing drawing</li> <li>3. Existing drawing of all electrical equipment</li> <li>4. Existing drawing of all air conditioning equipment</li> <li>5. Index sheet of the after improving drawing</li> <li>6. After improving drawing of improved electrical equipment</li> <li>7. After improving drawing of improved air conditioning equipment</li> <li>8. After improving drawing of film, insulation, and ceramic coating</li> </ol>	<p><b>Mistake number 8</b></p> <ol style="list-style-type: none"> <li>1. The replacement should consider ceiling system, power supply, finishing, and satisfaction of the user</li> <li>2. If the improving is complex the detail drawing should show in the energy conservation improvement drawing</li> <li>3. The drawing must show the refrigerant line between FCU - CDU</li> </ol>
<p><b>Mistake number 9</b></p> <ol style="list-style-type: none"> <li>1. The system are existing or after improving air conditioning, existing or after improving electrical system.</li> <li>2. Show the number of room and type of ceiling in room in the bottom of the energy conservation improvement drawing. If room number 101 is the concrete ceiling, it shows 101 (C) in the bottom of drawing</li> </ol>	<p><b>Mistake number 7</b></p> <p>The cover of the energy conservation improvement drawing should be written as this form</p> <p>Energy Conservation Improving Drawing Energy Conservation in Government or State owned Building Project</p> <p>Building ... Address ...</p> <p>Bureau of Energy Regulation and Conservation Department of Energy Development and Promotion Ministry of Science, Technology, and Environment</p>
<p>LOGO</p> <p>Energy Conservation Center of Thailand Implementing Agency</p>	<p><b>Mistake number 10.</b></p> <p>Sign the name of the engineer with the Engineering Licence number at least 2 sets in the final energy conservation improvement drawings as form of drawing</p>
<p>LOGO &amp; NAME</p> <p>Company...Auditor....</p> <p>Mr.....Electrical Engineering Licence number....</p> <p>Mr.....Mechanical Engineering Licence number....</p> <p>Project .....</p> <p>Building Name .....</p> <p>Floor .....</p> <p>System .....</p> <p>Date No. of Revision</p> <p>Scale Paper Size</p> <p>Draftman</p> <p>Reviser</p> <p>Page From</p>	

**Mistake 12**  
Table of lighting system symbol

BALLAST		SIZE		MOUNTING		CEILING		COVER		REFLECTOR	
SYMBOL	def <sup>n</sup>	SYMBOL	def <sup>n</sup>	SYMBOL	def <sup>n</sup>	SYMBOL	def <sup>n</sup>	SYMBOL	def <sup>n</sup>	SYMBOL	def <sup>n</sup>
M	Magnetic		1x18		Surface	G	Gypsum Board	-	Bara	-	non reflector
D	Low Watt		2x18		Hanging	T	T-Bar	C	Clear	R	reflector
H	High Power		3x18		Recess	F	Floor/Concrete	S	Sifple		
E	Electronics		4x18		new fixture	W	Wood	O	Opal		
	only ballast		1x36			A	Asbestos Cement	L	Louver		
	replacement		2x36					P	Prismatic		
			3x36					B	Fish Bone		
			4x36								
			32 W								
			Incandescent . . watt								
			compact Fl.								

**Mistake 11**  
Table of air conditioning system symbol

symbol	description
	Fancoil Unit Ceiling Type
	Fancoil Unit Standing Type
	Fancoil Unit wall Type
	Window Type
	Condensing Unit
	Package Type
	Bimetal Thermostat
	Electronics Thermostat
	Chiller
	Three Phase
	New Capacity

*Mistake number 13*

1. Use Ms Word or Ms Excel with font Cordia UPC and appropriate size in A4 Paper for report making.
2. Use Autocad Release 14 for Energy Conservation Improvement Drawing

**Energy Audit Report**

**Energy Conservation in Government or State-owned Building**

**(Contract number ....99)**

*Mistake number 14*

The scale in energy conservation improvement drawing is used for the frame of building only excluding the symbol of equipment

*Mistake number 15*

The contract number between ECCT and DEDP

**Building Name**

**Submitted to**

**Bureau of Energy Regulation and Conservation  
 Department of Energy Development and Promotion  
 Ministry of Science, Technology, and Environment**

**By**

**Energy Conservation Center of Thailand**

**Co-operate with**

.....

---



**Acception Letter**  
**Energy Conservation Plan**

ECCT is an Implementing Agency of DEDP to revise the potential of the energy conservation in the government or state-owned building. ECCT cooperates with ..... found that the low efficiency in the building as the enclosure.

Hereinafter .....building name.....accepts the list of energy conservation equipment and ready to join in the installation phase

Name .....  
Signature ( ..... )  
Title .....

This is the letter confirms that ECCT already check these item before send the report to the Department of Energy Development and Promotion

1. General data

- 1.1 Using area
- 1.2 Electrical energy consumption and cost per unit
- 1.3 Proportional of the energy using in each system
- 1.4 Average EER (Btu.hr/watt) before and after improving
- 1.5 Air conditioning system index (Btu.hr/m)<sup>2</sup>
- 1.6 The illumination before and after improving
- 1.7 Average electrical index (Watt/m)<sup>2</sup>
- 1.8 OTTV, RTTV , and input of OTTV and RTTV.
- 1.9 Number of equipment in air conditioning system conforms to the energy using and saving
- 1.10 Number of equipment in lighting system conforms to the energy using and saving

2. Energy conservation plan for air conditioning and lighting system

- 2.1 Saving, average electrical cost, percent of saving, number of improved equipment
- 2.2 EIRR
- 2.3 Cost of investment as median price
- 2.4 Factor F calculation

3. Bill of quantity

- 3.1 Check the number and median price of new equipment (material cost , labor cost, finishing cost ,miscellaneous cost

This report was already approved as the item 1, 2, and 3.

Reviser 1 .....  
(.....)

Title .....

Reviser 2 .....  
(.....)

Title .....

This is the letter confirms that consultant company already check these item before send the report to the Energy Conservation Center of Thailand

1. General data

1.1 Using area

1.2 Electrical energy consumption and cost per unit

1.3 Proportional of the energy using in each system

1.4 Average EER (Btu.hr/watt) before and after improving

1.5 Air conditioning system index (Btu.hr/m<sup>2</sup>)

1.6 The illumination before and after improving

1.7 Average electrical index (Watt/m<sup>2</sup>)

1.8 OTTV, RTTV , and input of OTTV and RTTV.

1.9 Number of equipment in air conditioning system conforms to the energy using and saving

1.10 Number of equipment in lighting system conforms to the energy using and saving

2. Energy conservation plan for air conditioning and lighting system

2.1 Saving, average electrical cost, percent of saving, number of improved equipment

2.2 EIRR

2.3 Cost of investment as median price

2.4 Factor F calculation

3. Bill of quantity

3.1 Check the number and median price of new equipment (material cost , labor cost, finishing cost ,miscellaneous cost

This report was already approved as the item 1, 2, and 3.

Reviser 1

(.....)

Title

.....

Reviser 2

(.....)

Title

.....

Technical Data

Energy using area	.....	m <sup>2</sup>
Air conditioning area	.....	m <sup>2</sup>
Energy consumption	.....	kWh/year
Average electrical energy cost	.....	baht per unit
proportion of the energy using in each system		
Air conditioning system	.....	%
Lighting system	.....	%
Others	.....	%

This page is the conclusion about the energy index of each system in the building both before and after improvement

Before improving      after improving

Air conditioning system

Average EER (Btu/h/Watt)	.....	*
Average air conditioning system index (Btu/h/m <sup>2</sup> )	.....	**

Lighting system

Illumination (lux)	.....	***
Average lighting system index (Watt/m <sup>2</sup> )	.....	

Envelope system

OTTV (Watt/m <sup>2</sup> )	.....	
1. Building...	.....	
2. Building...	.....	
RTTV (Watt/m <sup>2</sup> )	.....	
1. Building...	.....	
2. Building...	.....	

**Mistake number 16**  
Calculate the average lighting system index as this formula  
Existing (w/m<sup>2</sup>) - kwh/year saving (w/m<sup>2</sup>)

Remark

1. Air conditioner
  - 1.1 Used air conditioner more than 8 years ..... sets
  - 1.2 Used air conditioner >7-8 years ..... sets
  - 1.3 .....
2. Measures of OTTV improvement cannot be implemented because ...
3. Measures of RTTV improvement cannot be implemented because ...

**Mistake number 17**  
The OTTV and RTTV improvement measures cannot be implemented because the following reasons  
1. EIRR less than 9%  
2. The OTTV and RTTV after improving is over the standard  
3. The improper of the site

- \* The EER of new air conditioner lower than 25000 Btu/h is more than 10.6 Btu/h/Watt  
The EER of new air conditioner up to 25000 Btu/h is more than 9.6 Btu/h/Watt
- \*\* The average capacity of air conditioner after improving is not less than the existing capacity
- \*\*\*The average illuminant after improving is higher than the existing illuminant from the assesment and the illuminant should not less than 350 lux in working plane of room.

Bill of Quantity

Energy Conservation in Government or State-owned Building

Address.....

Mistake number 18

1. The right mark means that blank should be filled in.
2. The wrong mark means that blank should not be filled in.
3. The finishing cost includes the miscellaneous cost

No.	Material	Quantity	Unit	Material Cost		Labor Cost		Removing Cost	Finishing Cost	Total
				Unit Price	Total	Unit Price	Total			
A	Lighting System									
1	Compact Fluorescent .....w				✓		✓	✗		
	total 1									
2	Reflector Luminary Surface, Louver (Wide ... cm) type 1x36 w High Efficiency (Triphosphor Coating type) Fluorescent .....w		set lamp		✓		✓	✗		
	Finishing Cost	1	set						✓	
	total 2									
3	Electronics Ballast 18 W 36 W		each each		✓		✓	✗	✗	
	total 3									
	total A									

Bill of Quantity

Energy Conservation in Government or State-owned Building

Address

No.	Material	Quantity	Unit	Material Cost		Labor Cost		Removing Cost	Finishing Cost	Total
				Unit Price	Total	Unit Price	Total			
B	Air Conditioning System									
1	High EER air conditionet with electronics thermostat more than 12000 Btu/h more than 60000* Btu/h		set		✓		✓	✓	✓	✓
	<i>Mistake number 21.</i> put the * mark after the capacity of the 3 phase air conditioner		set							
	<i>Mistake number 22</i> show the list of the air conditioner in each capacity		set							
	<del>Finishing Cost</del>		<del>set</del>							
	<b>Total I</b>									
2	Ceramic Coating		sq.m							
	<b>Total B</b>									
	<b>Total A and B</b>									
	<b>Factor F</b>									
	<b>Total in Word....</b>									

*Mistake number 19*  
The finishing cost of the air conditioner is  
500 baht per each set

*Mistake number 22*  
show the list of the air conditioner in each capacity

*Mistake number 21.*  
put the \* mark after  
the capacity of the 3  
phase air conditioner

*Mistake number 20*  
Do not forget to fill in  
these blocks

\*Factor F Calculation

Budget.....A..... Factor F.....M.....

Budget.....B..... Factor F.....N.....

Budget.....C..... Factor F.....N - [(C-B)/(A-B)] X (N-M).....

Energy Consumption	.....	kWh/year
Proportion of the Energy Using of Each System		
Air Conditioning System	.....	%
Lighting System	.....	%
Others	.....	%

No.	Item	Before Improving	After Improving	Diference
1	60% Operating <i>Mistake number 23</i>			1
1.1	Saving (kWh/year)	Before improving figure should be more than after improving		
1.2	Saving (Baht/year)			
1.3	Investment (baht)	Before improving figure should be less than after improving		-
1.4	Payback Period(year)			-
1.5	EIRR%	Before improving figure should be more than after improving		
1.6	Number of Luminary (set)	Before improving figure should be less than after improving		
1.7	Electronics Ballast (set)			
1.8	Number of Lamp (Lamp)			
1.9	Lighting System Index (watt/m) <sup>2</sup>	Before improving figure should be more than after improving		
1.10	Illuminant (lux)	Before improving figure should be less than after improving		
2	100% Operating <i>Mistake number 24</i>			
2.1	Saving (kWh/year)			
2.2	Saving (baht/year)			
2.3	Payback Period(year)			-
2.4	EIRR%			-

**Abstract**

This report is part of the Energy Conservation in Government or State-owned Building project which ECCT is the implement agency of the Department of the Department of Energy Development and Promotion to study the potential of the energy conservation. The Energy Conservation Center of Thailand co-operates with .....to audit and analyze the characteristic of the energy consumption in building.

In this report the measures of energy efficiency are analyzed and concluded hereinafter

**1. Electrical and Thermal System**

The energy conservation plan will save the energy .....baht/year by investing .....baht

The measures are

1. The high EER air conditioner with electronics thermostat replacement
2. Film coating
3. Ceramic coating
4. Lighting system
  - 4.1 Compact fluorescent replacement
  - 4.2 Electronics ballast replacement
  - 4.3 Reflector luminary replacement

**Mistake number 25**  
The same as table 5

**Mistake number 26**  
The same as table 5 and should cost between 5 and 10 million baht

**Mistake number 28**  
- The measures list here likes table 5  
- The measures should cover both air conditioning and lighting system

**Mistake number 27**  
Measures of only electronics thermostat replacement is quit.

**Mistake number 29**  
The same as table 5.3

**Mistake number 30 and 31** The same as table 5.3 item 4

The improving of the lighting system ,which the illumination should not less than the existing,invests .....baht and saves .....baht. The EIRR is .....%. If the quality of life is improved as the commitment number 3/1998 (dated on 14 October 1998) of the committee of the Energy Conservation Fund, the investment increases .....baht. Thus the saving reduces to .....baht and the EIRR is.....% %

**Mistake number 32**  
The same as table 5.3 item 6

**Mistake number 33**  
- The OTTV after improving has to show here if the OTTV before improving is more than 55 watt/m<sup>2</sup>  
- If the measures can not be implemented, the reason should be explained

**2. Envelope**

Building.....

**Mistake number 34**  
The same as appendix B

OTTV before improving ..... watt/m<sup>2</sup>  
 RTTV after improving ..... watt/m<sup>2</sup>  
 OTTV before improving ..... watt/m<sup>2</sup>  
 RTTV after improving ..... watt/m<sup>2</sup>

**Mistake number 35**  
- The OTTV after improving has to show here if the OTTV before improving is more than 55 watt/m<sup>2</sup>  
- If the measure can not be implemented, the reason should be explained



Contents

	Page
<b>1. General data and characteristic of the building</b>	1-1
<b>2. Characteristic of the energy using</b>	2-1
2.1 Electrical using in organization	
2.2 Electrical using in building	
2.3 Water using	2-n
<b>3. Suggestion for energy conservation</b>	3-1
3.1 Suggestion for electrical saving	3-1
3.1.1 Air conditioner maintenance	3-1
3.1.2 High EER air conditioner with electronics thermostat replacement	
3.1.3 Film coating	
3.1.4 Insulation tiling	
3.1.5 Ceramic coating	
3.2 Suggestion for lighting saving	
3.2.1 Compact fluorescent replacement	
3.2.2 Reflector Luminary Replacement	
3.2.3 Electronics Ballast Replacement	
3.3 Suggestion for thermal saving	
3.3.1 Boiler tuning	
3.3.2 Boiler insulating	
3.3.3 Condensate recovery	3-n
<b>4. Potential of the Energy Conservation</b>	4-1
<b>5. Energy Conservation Plan</b>	5-1

Mistake number 36  
The measures of the air conditioner includes electronics thermostat

Mistake number 37  
the list of the measures here likes the measures in the potential of the energy conservation

Mistake number 38  
The thermal measures can be suggested if the overall budget of building is less than 3 million baht

Appendix

	Page
<b>Appendix A</b>	a-1
A.1 Electrical power distribution	
A.2 Air conditioning system	
A.3 Lighting system	
	b-1
<b>Appendix B</b>	
B.1 OTTV before improving	
B.2 RTTV before improving	
B.3 OTTV after improving	
B.4 RTTV after improving	
	c-1
<b>Appendix C</b>	
The data for controlled building	
	d-1
<b>Appendix D</b>	
The data for government or state-owned building	
	e-1
<b>Appendix E</b>	
Iso - lux calculation	
	f-1
<b>Appendix F</b>	
Input of OTTV and RTTV	

Mistake number 39  
Put the improvement drawing before improving in this section

Mistake number 40  
Put the picture of the luminary before improving and the iso-lux drawing in this section

Mistake number 41  
Use software Q-Save only for

Mistake number 42  
Check the completion of the data

Mistake number 43  
The input after improving requires only th diferent data

**1. General Data and Characteristic of the Building**

**1.1 General Data**

- Building name : .....
- Address : .....
- Telephone number : ..... Mistake number 44  
Long distance code for provincial province
- Characteristic : .....
- Government time : From.....to.....total.....hr/day or.....hr/day
- Working time : From.....to.....total.....hr/day or.....hr/day
- Opening time : .....
- Employee : ..... person
- Number of bed : ..... beds Mistake number 45  
Number of bed is used for hospital only
- Using area : ..... m<sup>2</sup>
- Air conditioning area : ..... m<sup>2</sup>
- Name of cooperator : ..... Mistake number 46  
Write the right title of the co-operator
- Title or position : .....
- Telephone number : .....
- Facsimile Number : .....

**1.2 Characteristic of the Building**

Building ..... is the squar/rectangular building which has .....floors  
s .....years. The characteristic are

- Wall : .....
  - Window : .....
  - Door : .....
  - Roof : .....
  - Floor : .....
  - Overhang : .....
- Mistake number 47  
The charactenstic should be  
completed and accorded to the data  
in the OTTV calculation

**1.2.1 Characteristic of the Opaque Wall**

*Mistake number 48*  
Write the name of building  
although there is only one

Building

Characteristic	Type of material / Thickness (mm.)						
	layer 1	thickness	layer 2	thickness	layer 3	thickness	Color of outside
1. ....							
<p><i>Mistake number 50</i> The example of the opaque wall characteristic are brick wall cement, brick eall with insulation, marble, concrete wall</p>							<p><i>Mistake number 49</i> The example of the color are light, medium, and dark</p>
п. ....							

**1.2.2 Characteristic of Transparent Wall**

Building.....

Characteristic	Number of layer	Type of transparent wall/ Thickness (mm.)			Type of Overhang
		Thickness	Type	SC*	
1. ....					
<p><u>Mistake number 51</u></p> <p>The examples characteristic of transparent wall are normal, 2 layer, film coated glass, and bronze glass</p>					<p><u>Mistake number 52</u></p> <p>The example characteristic of overhang are straight, dome, long overhang, and short overhang</p>
n. ....					

\* SC : Shading coefficient

**1.2.3 Characteristic of Roof**

Building....

Characteristic	Type of material / Thickness (mm.)						
	Layer 1	Thickness	Layer 2	Thickness	Layer 3	Thickness	Outside color
1. ....							
n. ...	<div style="border: 1px solid black; padding: 5px;"> <p><b>Mistake number 53</b></p> <p>The example of the characteristic of roof are concrete, concrete with insulation, and others</p> </div>						


**1.2.4 Characteristic of the Building Envelope**

Building.....


Side	Direction	Opaque wall area (m2)		Transparent wall area (m2)		Proportion of transparent to overall wall
		Air conditioning	total	Air conditioning	total	
Front						<div style="border: 1px solid black; padding: 5px;"> <p><i>Mistake number 54</i></p> <p>Fix two digit of the decimal part</p> </div>
Back						
Right						
Left						

**1.3 Building Picture**

Mistake number 55  
Four side of picture per each building




**Front View**




**Back View**



**Building Picture**



**Left View**



**Right View**

### 1.4 Location

The map in the organization

The map of building with north grid

## 2. Characteristic of the Energy Using

### 2.1 Energy Using in Organization

Energy Consumption Peak Demand Load Factor Transformer Capacity Voltage Electrical Energy Index Power Factor Electrical Energy Cost	<div style="border: 1px solid black; padding: 5px; width: fit-content;"> <u>Mistake number 56</u>                      If there is no load factor or peak demand, write the - mark. Do not omit it.                 </div> <div style="border: 1px solid black; padding: 5px; width: fit-content; margin-top: 10px;"> <u>Mistake number 57</u>                      PEA. 11,22,33 kV /230,400 kV                      MEA. 12,24,66 kV/230,400 kV                 </div>	<div style="border: 1px solid black; padding: 5px; width: fit-content; margin-top: 10px;"> <u>Mistake number 58</u>                      The data here is the same as to the table 2.2.1                 </div>	kWh/year kW percent kVA Volt kWh/m <sup>2</sup> /year baht/kWh
--	--	---	--

### 2.2 Energy Using in Building

Building..... used electrical energy ..... % of the organization or ..... kWh/year. The proportion of each system are

Air conditioning system Lighting system Others	<div style="border: 1px solid black; padding: 5px; width: fit-content;"> <u>Mistake number 59</u>                      The normal ratio are 60:20:20. 70:20:10. and 80:10:10. If there is abnormal, should show the reason                 </div>	% % %
--	---	-------------

2.2.1 Energy Consumption Table

Month	Peak Demand	Consumption	Cost	Load Factor	Cost per unit
	(kWh)	(kWh)	(baht)	%	(baht/kWh)
	A	B		$B \times 100 / (A \times \text{hour in month})$	
Total	-			-	
monthly average	-			-	
yearly average	-	C		$c. (kW \text{ maximum} \times 8760) \times 100$	

2.2.2 Graph of the Energy Consumption

2.2.3 Energy Using in Air Conditioning System

Building.....

**Mistake number 60**  
Write the building name

**Mistake number 61**  
Separate each table for each building

No.	Capacity (Btu.h)	Type	Number in each age					Total sets	Total (Btu)
			< 3	3 - 5	>5-6	>6-7	>7 - 8		
Total									

Air conditioning area  $m^2$   
 Top floor air conditioning area  $m^2$   
 Air conditioning index Btuh/m2  
 Energy consumption of air conditioning system kWh/year  
 Average EER of building Btuh/watt

**Mistake number 62**  
Select the data from the table in A.2.2 of each building to calculate

Organization

**Mistake number 63**  
Conclude from all building

No.	Capacity (Btu.h)	Type	Number in each age					Total sets	Total (Btu)
			< 3	3 - 5	>5-6	>6-7	>7 - 8		
Total									

Conclude  $m^2$   
 Total air conditioning area  $m^2$   
 Top floor air conditioning area Btuh/m2  
 Total air conditioning index kWh/year  
 Total energy consumption of air conditioning system Btuh/watt  
 Total average EER of building

**Mistake number 64**  
Write the conclude table if there are more than one building

**Mistake number 66**  
If the age of the air conditioner is more than the age of the building, please show the reason

**Mistake number 65**  
The same as table A.3.3

### 2.2.4 Energy Using in Lighting System

The energy using in lighting system are concluded in the table below

No.	Type of lamp	Type of luminary	Type of cover	Lamp per luminary (Lamp/Luminary)	Number of Luminary	watt/luminary	Ballast loss (watt/Luminary)	Total watt (watt)
1								
2								
3								
4								
Total								

*Mistake number 68*  
 - The loss of ballast 18,20,32,36,40 w. is 10 w.  
 - The loss of the low watt loss ballast is 5.5 w.

Building.....

Using area

m<sup>2</sup>

Average lighting system index

watt/m<sup>2</sup>

Energy consumption

kWh/year

Conclusion

*Mistake number 67*  
 Conclude the data from  
 every building and like  
 A.4

Using area

m<sup>2</sup>

Average lighting system index

watt/m<sup>2</sup>

Energy consumption

kWh/year

### 2.3 Water Using

Volume : ..... m<sup>3</sup>/year  
Cost : ..... baht/m<sup>3</sup>  
Water using index : ..... m<sup>3</sup>/man-year

**Remark** ..... *Mistake number 69*  
m<sup>3</sup>/bed-year in the case of the hospital building

*Mistake number 70*  
Show the reason of the case of no water using

### 3. Suggestion for Energy Conservation

#### 3.1 Suggestion for Electrical Saving

##### 3.1.1 Air Conditioner Maintenance

###### Data from Auditing

There are .....sets of existing air conditioner which have not been replaced. The capacity is .....ton and consume.....kWh/year. The non maintenance condition makes the energy consumption of the air conditioner more than the maintenance condition as the data in table below.

	The non maintenance air conditioner	The maintenance air conditioner	The difference data
EVAP TEMP	7.2 °C	7.2 °C	-
COND TEMP	54.4 °C	51 °C	3.4
AMBIENT	35 °C	35 °C	-
POWER (W.)	3700	3590	110
Btu	27900	29340	1440
Btu/Watt	7.52	8.17	0.63

(The data in table are quoted from technical data of Compressor energy efficiency)

$$\begin{aligned} \text{Saving} &= \frac{0.63 \times 100}{8.17} \\ &= 7.7 \quad \% \end{aligned}$$

###### Suggestion

The air conditioner always maintains for the efficiency of the heat transfer at condensing coil by the following procedure.

###### 1. Monthly measure

- Use the compressed air to clean the condensing coil, evaporater coil, and filter.
- Check the controlling system such as the temperature control system
- Record the energy consumption, current, voltage of compressor, motor, and fan



2. Every 6 month

- Do the big cleaning all coil by water cleaning.

After maintaint the air conditioner

Saving	=	.....	x	0.077	kWh/year
	=	.....			
Saving in term of baht	=	.....	x		baht/year
	=	.....			baht/year

**Investment**

The maintenance measure invests 700 baht/sets/year and 2000 baht for the air conditioner which the capacity is more than 60000 Btu.

Payback period	.....	year
Economic Investment Rate of Return	.....	%

3.1.2 The measure of high EER air conditioner with electronics thermostat replacement

**Data from Auditing**

There are ....sets of low EER air conditioner. The total capacity is.....Btu

*Mistake number 72*

Select the data from table 5.1 for saving calculation

**Example of calculation**

Select one of the air conditioner which the capacity is more than 25000 Btu for calculation

\* EER (Energy Efficiency Ratio) of the example air conditioner = ..... Btu/hr/Watt

*Mistake number 71*

The cost of removing the existing air conditioner with the capacity more than 60000 Btu is calculated as the appropriate of the condition of the site work

= 12000/( ..... x1000) kW/ton  
 = ..... kW/ton

\* EER (Energy Efficiency Ratio) of the high EER air conditioner = 9.6 Btu/hr/Watt

= 12000/( 9.6 x1000) kW/ton  
 = 1.25 kW/ton

(kW/ton as stated is the energy consumption for the real cooling capacity 1 ton, not as the name plate)

*Mistake number 73*

Operating Factor is the same figure as the operating in appendix A ↓

Saving = [(...-1.25)x...tonx hr/day x day/year x factor] kW/year

Saving in term of baht = ..... X ..... baht/year

*Mistake number 74*

This formular for saving is used for only the capacity of the difference of the new and existing air conditioner is less than 6000 Btu. If the difference is more than 6000 Btu, use the following formular:  
 (existing kW ton X existing ton - new kW ton X new ton ) X hr day X day year X factor

The air conditioner is replaced dual with the electronics thermostat

Saving = existing Btu /12000 X kW/ton x hr/day x day/year X factor X 0.13

*Mistake number 75*

Use the same kW/ton of the same example air conditioner

Saving in term of baht = ..... X ..... kWh/year

*Mistake number 76*

The Btu for calculation bases on the existing for easy in calculaton although the 13 % of saving is from the following concept  
 The existing air conditioner with existing electronicmostat - The new air conditioner with new electronics thermostat

Total energy saving = ..... Kwh/year

Total saving in term of baht = ..... baht/year

**Example**

Select one of the air conditioner which the capacity is less than 25000 Btu for calculation

\* EER (Energy Efficiency Ratio) of the example air conditioner = ..... Btu/hr/watt  
 = 12000/( ..... x1000) kW/ton  
 = ..... kW/ton

\* EER (Energy Efficiency Ratio) of the high EER air conditioner = 10.6 Btu/hr/watt  
 = 12000/( 10.6 x1000) kW/ton  
 = 1.13 kW/ton

(kW/ton as stated is the energy consumption for the real cooling capacity 1 ton, not as the Name Plate)

Saving = [(-1.13)x...tonx hr/day xday/year x factor] kW/year  
 = ..... kW/year

Saving in term of baht = ..... x..... baht/year  
 = ..... baht/year

The air conditioner is replaced dual with the electronics thermostat

Saving = existing Btu /12000 X kW/ton x hr/day x day/year X factorX0.13  
 = ..... kWh/year

Saving in term of baht = ..... x ..... baht/year  
 = ..... baht/year

Total energy saving = ..... kWh/year

Total saving in term of baht = ..... baht/year

**Suggestion**

From auditing the low EER air condition should be replaced as the list of new air conditioner

There are .....sets as the location in the energy conservation improvement drawing. The saving after improving is.....kwh/year and .....baht/year

*Mistake number 77*  
 The same data as the list of new air conditioner

*Mistake number 78*  
 The investment data is the same as the investment in the table 5

**Investment**

The new high EER air conditioner are.....sets. The material cost is .....baht

The material cost is .....baht, the removing cost is .....baht, the cost of installation is....baht, and the finishing cost is .....baht

Payback period ..... year  
 Economic Investment Rate of Return ..... %

3.1.3 The measures of film coating

Data from Auditing

Building.....has the transparent wall .....m<sup>2</sup> and the opaque wall .....m<sup>2</sup>.

The OTTV is.....watt/m<sup>2</sup> while the standatd figure is 55 watt/m<sup>2</sup>. The overall existing transparent wall of the building is the .....mm glass.

**Mistake number 79**  
In the energy conservation improvement drawing must show the area of film coating.

The shading coefficient of the existing transparent wall is  
The shading coefficient after improvement reduces the OTTV to ..... watt/m<sup>2</sup>

The difference of OTTV = ..... watt/m<sup>2</sup>

**Mistake number 80**  
The area of saving calculation is the same as the area in the OTTV calculation

The overall area of wall = ..... m<sup>2</sup>

The reduced heat = (.....-.....)x(.....+.....)x3,414/1000 Btu/hr

(1 kw of heat equals to 3414 Btu/hr)

= ...../12000 ton

The saving electrical energy

**Mistake number 81**  
The hour for calculation should be less than 12 hours of daylight shining

**Mistake number 82**  
Transform the average EER to kw/ton for calculation

= .....x hr/dayk x day/year x operating factor of x kW/ton kWh/year

**Mistake number 83**  
The reflectance of the new film should be less than 0.2

= ..... kWh/year

= ..... x ..... baht/year

= ..... baht/year

Suggestion

The measure of film coating will reduce the heat gain from the outside. So the saving is .....  
.....kwh/year or .....baht/year.

Investment

**Mistake number 84**  
There is no miscelleneous cost and the finishing cost in the film coating measures

The overall film area is .....m<sup>2</sup>. The price of film coating is 950 baht/m<sup>2</sup>

The total cost of investment is .....l

Payback period ..... year

**Mistake number 85**  
Area of film coating maybe more than the area of conditioning area

Economic Investment of Return

**Mistake number 86**  
If there is the existing film and the OTTV is more than 55 watt/sq.m., the auditor should check that the existing film could be removed or not.

**Mistake number 87**  
The EIRR can be calculated for each or overall building to make the EIRR more than 9 %.

3.1.4 The measures of insulation tiling

Data from Auditing

The area of the ceiling at the top floor which gain the heat without the insulation tiling is .....m<sup>2</sup>

The capacity in the top floor is .....ton which consumes the electrical energy .....kW. The existing RTTV is..... W/m<sup>2</sup>

Suggestion

The ceiling of the top floor without the insulation tiling makes the high load to the air conditioner. So the insulation can reduce the heat gain in the building and the electrical energy consumption of the air conditioner.

After tiling the insulation the energy consumption of the air conditioning system reduces

as the calculation

The RTTV before improving = A

The RTTV after improving = B

The difference of RTTV = A-B

Tiling area = C

The reduced heat gain = (A-B)xCx3414/1000

(1 kW heat equals to 3,414 Btu/hr)

Energy saving

**Mistake number 93**  
The investment cannot include the miscellaneous cost and finishing cost

**Mistake number 90**  
Select only one measures in the case of both of measures of insulation and ceramic coating can be implemented.

= ...../12000 ton  
= .....x hr/day x day/year x operating factor x kW/ton kWh/year  
= ..... kWh/year  
= ..... x ..... kWh/year  
= ..... baht/year  
= ..... baht/year

**Mistake number 91**  
kW ton is calculated from the average EER from auditing

**Mistake number 89**  
The measures of insulation is the first priority when RTTV of the building is more than 25 watt sq.m.. If the EIRR is less than 9% or it is difficult to tile the insulation, the measures of ceramic coating is the second priority. The OTTV and RTTV calculation still shown both measures of insulation and ceramic coating

**Mistake number 88**  
The area for energy saving is the same as the ara for RTTV calculation

watt/m<sup>2</sup>  
watt/m<sup>2</sup>  
watt/m<sup>2</sup>  
m<sup>2</sup>  
Btu/hr  
ton

Investment

The air conditioning area at the top floor ceiling is.....m<sup>2</sup>. The price is .....baht/m<sup>2</sup>

The labor cost is .....bah/m<sup>2</sup> Total cost of investment is .....baht.

Payback period

year

Economic Investment Rate of Return

%

**Mistake number 92**  
Show the real area of the film coating

3.1.5 The measures of ceramic coating

Data from Auditing

The capacity of the air conditioner on the top floor is .....Btu which consume energy ...kW/ton  
 The roof area which gain the heat is .....m<sup>2</sup> The RTTV is .....watt/m<sup>2</sup> which is higher than 25 watt/m<sup>2</sup> as  
 stated in the act of energy conservation.

*Mistake number 96*  
 The median price of every color of ceramic coating is the same.

*Mistake number 95*  
 Show the calculation of the area for ceramic coating

Suggestion

After coating the .....color ceramic on the roof, the RTTV reduces to .....watt/m<sup>2</sup>  
 The load of air conditioning system reduces too.

*Mistake number 97*  
 The area of ceramic coating is the same as the area of RTTV calculation

RTTV before improving	=	A		watt/m <sup>2</sup>
RTTV after improving	=	B		watt/m <sup>2</sup>
The difference of RTTV	=	A-B		watt/m <sup>2</sup>
Ceramic coating area	=	C		m <sup>2</sup>
The difference of RTTV	=	(A-B)xCx3414/1000		Btu/hr
(1kW of heat equals to 3414 Btu/hr)	=	...../12000		ton

Energy saving

*Mistake number 94*  
 The area of ceramic coating should consider the slope, the eaves, and the curb.  
 The double curved roof and the big or small curved roof which has 15-25 degree of slope, use the factor 1.06 to multiple into the non slope area and factor 1.02 to multiple into the non curved area. If the degree of slope is 25-30 degree the factor is 1.12 and 1.25

	=	.....x hr/day x day/year x factor x kw/ton	kWh/year
	=	.....	kWh/year
	=	..... x .....	baht/year
	=	.....	baht/year

*Mistake number 99*  
 The area in the investment is all of the roof because of the appropriation.

Investment

The area of ceramic coating is.....m<sup>2</sup> The labor cost is .....baht/m<sup>2</sup>  
 The total cost is .....baht

Payback period

Economic Investment Rate of Return

*Mistake number 98*  
 The area of ceramic coating should has the water drain  
 year  
 %

**3.2 Suggestion for lighting saving**

**3.2.1 The measures of compact fluorescent replacement**

**Mistake number 100**  
Simulate the illumination by software EASY LUX version 2.06 by selecting direct calculation

**Data from auditing**

**Mistake number 101**  
This measures is used for compact fluorescent only

**Mistake number 102**  
The replacement should consider the dimension and the installation of the compact fluorescent

There are some of the incandescent lamp in the building which should change into compact fluorescent as the list below

Incandescent ..... watt ..... lamp

**Suggestion**

After replace the incandescent by the compact fluorescent the saving is

Saving = ..... kwh/year  
**Mistake number 103**  
Use the age of compact fluorescent only 4 years for EIRR calculation = ... kwh/year  
Saving in term of baht = ... baht/year  
= ..... baht/year

**Investment**

The compact fluorescent with electronics ballast.....sets costs.....baht/sets  
The labor cost is .....baht/lamp. Total cost is .....baht  
Payback period ..... year  
Economic Investment Rate of Return .....

**Mistake number 104**  
The EIRR calculation should select the age of each equipment

### 3.2.2 The measures of reflector luminary replacement

<u>Mistake number 105</u> The existing luminary can be replaced only the age is more than 3 years	<u>Mistake number 106</u> Use the 32-18 = 14 watt for the saving from the replacement of the reflector luminary	<u>Mistake number 107</u> The measures of reflector luminary replacement should replace the ballast and the lamp in that luminary
--	--	--

#### Data from Auditing

The existing luminary can be replaced with the reflector luminary as the list below.

Mistake number 108 The hanger of the existing luminary should not use for the new reflector for the better distribution of the light.

- Reflector luminary	...	x	...	watt cover with.....	install by....	.....	sets
Change to	...	x	...	watt cover with.....	install by....	.....	sets
- Reflector luminary	...	x	...	watt cover with.....	install by....	.....	sets
Change to	...	x	...	watt cover with.....	install by....	.....	sets
- Reflector luminary	...	x	...	watt cover with.....	install by....	.....	sets
Change to	...	x	...	watt cover with.....	install by....	.....	sets
- Reflector luminary	...	x	...	watt cover with.....	install by....	.....	sets
Change to	...	x	...	watt cover with.....	install by....	.....	sets

#### Remark

The existing layout should be set and increase the reflector luminary as list.

1	Increase the reflector luminary	...	x	...	watt cover with.....	install by....	.....	sets
2	Increase the reflector luminary	...	x	...	watt cover with.....	install by....	.....	sets
3	Increase the reflector luminary	...	x	...	watt cover with.....	install by....	.....	sets

#### Suggestion

The existing luminary was covered by the opal cover which reduces the efficiency of the luminary.

If use the reflector luminary with silver coating, the half number of the lamp reduces with the same illumination.

Mistake number 109  
The dimension of the new and existing luminary should be the same

Saving	=	....	
	=	....	kWh/year
Saving in term of baht	=	....	x ....
	=	....	baht/year

Mistake number 110  
Show the lay out of the new reflector additional in the energy conservation improvement

Saving calculation  
[ Saving in one luminary x number of luminary ] - [ Energy consumption of the additional luminary X Additional lamp ]



3.2.3 The measures of electronics ballast

Data from Auditing

The existing magnetic ballast in the building is listed here

Magnetic ballast 36 watt	...	each
Magnetic ballast 18 watt	...	each
Magnetic ballast 32 watt	.....	each

Remark After improve the illumination, the electronics ballast must be increased as list below.

1. Electronics ballast 36 W type..x...each
2. Electronics ballast 18 W type..x...each

**Suggestion**

The existing magnetic ballast in the building can be replaced by the electronics ballast.

The saving from changing the 36 W magnetic ballast to electronics ballast is 12 W .The saving from changing the 18 W magnetic ballast to electronics ballast is 7 W.

$$\begin{aligned} \text{Saving} &= [(\dots \times 12) + (\dots \times 7) + (\dots \times 2) - (\dots \times 3)] \times \text{hr/day} \times \text{day/year} \times \text{factor} \times 1.0 / 1000 \\ &= \dots \text{ kW/year} \end{aligned}$$

$$\begin{aligned} \text{Saving in term of baht} &= \dots \times \dots \\ &= \dots \text{ baht/yeat} \end{aligned}$$

**Investment**

Replace the magnetic ballast to electronics ballast

The price of 36 W electronics ballast is .....baht

Total is.....baht

The price of 18 W electronics ballast is .....baht

Total is.....baht

The labor cost is .....baht/each. Total cost is .....baht

Payback period

Economic Investment of Return

4. Potential for Energy Conservation

Item	Investment			Saving		Payback period (year)	Economic investment rate of return EIRR (%)
	Material cost (baht)	Labor cost (baht)	Total (baht)	(kWh/year)	(baht)		
	<b>Electrical Energy</b>						
<b>1. Air conditioning system</b>							
1.1 Air conditioner maintenance							
1.2 High EER air conditioner with electronics thermostat replacement							
<b>Total</b>							
<b>2. Lighting system</b>							
2.1 Compact fluorescent replacement							
2.2 Reflector luminary replacement							
2.3 Electronics ballast replacement							
<b>Total</b>							
<b>Conclusion</b>							

*Mistake number 117*  
 Show all of the potential of measures here.

## 5. Energy Conservation Plan

Item	Investment			Saving		Payback period (year)	Economic investment rate of return EIRR (%)
	Material cost (baht)	Labor cost (baht)	Total (baht)	(kWh/year)	(baht/year)		
<b>Electrical Energy</b>	<i>Mistake number 123</i>	<i>Mistake number 122</i>		<i>Mistake number 121</i>		<i>Mistake number 118.</i>	
<b>1. Air conditioning system</b>	material cost from list of median price exclude VAT	Put the cost of removing + installation cost + finishing cost + miscellaneous cost in this block for air conditioning system.		kWh/year is on the left hand baht/year is on the right hand		Show the payback period and the EIRR for each measures	
1.1 High EER air conditioner with electronics thermostat replacement							
<b>Total 1</b>	<i>Mistake number 125</i>						
	material cost from list of median price exclude VAT						
<b>2. Lighting system</b>		<i>Mistake number 124</i>				<i>Mistake number 119.</i>	
2.1 Compact fluorescent replacement		Put the installation cost + finishing cost + miscellaneous cost				Show the payback period and the EIRR for each measures	
2.2 .....	<i>Mistake number 126</i>						
<b>Total 2</b>	Material cost from median price from list of median price exclude VAT					<i>Mistake number 120</i> Show the payback period and the EIRR for the lighting system	
<b>Conclusion</b>							

3. Total 1-2                      baht

4. Factor F                      baht

5. Total cost                      baht

Word of the cost of investment    baht

*Mistake number 127*

Check the word of  
investment as the figure.

Factor F calculation

*Mistake number 128*

The state ment number 2 is quoted from abstract

Remark: 1 High EER air conditioner can be replaced only the EIRR more than 9% only

2. Lighting system improvement should not make the illumination less than the existing by investing... baht. It saves.....baht and the EIRR is ..... %

If improve the quality of life as the commitment number 3/2541 (Number 15) of 14 October 1999, the cost of investment is increase .....baht

The saving reduces to ...baht and the EIRR is... %

5.1 List of the new air conditioner for .....floor.....Building.....

No.	Number FC....	Phase	Capacity (Btu)	Location	EER	kW/ton	New Capacity (Btu)	Saving (kWh/year)	Saving (Baht)	Material cost	Misceleneous cost	Removing cost	Installation cost	Finishing cost	Total (baht)	Payback period	EIRR%
1	FC....																
2																	
3																	
4																	
Total							<i>Mistake number 131</i> Show the total of each floor and of organization										

Remark

*Mistake number 132* Write remark in the bottom of the end of this table

1. The new capacity is not less than the existing capacity

2. The range of the same capacity.

1. 12000 - 13000 Btu
2. 16000 - 20000 Btu
3. 24000 - 25000 Btu
4. 32000 - 34000 Btu
5. 36000 - 42000 Btu

*Mistake number 130*

Criteria of air conditioner replacement

1. EER/EIRR
2. The age is more than 8 years
3. Important of room
4. EIRR is more than 9 %

*Mistake number 129*

The payback period should be between 4 and 6 years



5.3 Capability for lighting conservation

No.	Before improving		After improving		Average illumination (LUX)	Saving		Investment (baht)	Payback period	EIRR ( % )
	Type	Number	Type	Number		(kWh/year)	(baht/year)			
1	Lamp									
	1.1 Before improving									
	Total 1.1									
	1.2 After improving									
	Total 1.2									
2	Electronics ballast									
	2.1 Before improving									
	Total 2.1									
	2.2 After improving									
	Total 2.1									

Capability for lighting conservation

No	Before improving		After improving		Average illumination (LUX)	Saving		Investment (bath)	Payback period	EIRR ( % )
	Type	Number	Type	Number		(Kwh/year)	(bath/year)			
3	Luminary with lamp									
	3.1 Before improving									
	Total 3.1									
	3.2 After improving									
	Total 3.2									
	3.3 Measures of increased luminary									
	Total 3.3									
4	Total 1.1 + 2.1 + 3.1									
5	Total 1.2 + 2.2 + 3.2									
6	5 - 4									

**A.1 electrical power distribution**

A.1.1 single line diagram



Capacity of transformer kVA	Type	Voltage (kV)	Wire		Number of wire per phase
			Size (Sq.mm)	Length (m)	

**Transformer auditing**

Equipment	Capacity	Actual Load(kW)	V (Volt)	Ir (Amp)	Is (Amp)	It (Amp)	PF

Mistake number 135  
Should not audit in the afternoon because the load is lower than actual





A.2.2 EER data

A.1 ....years air conditioner

No.	Number FC.....	Location and capacity Btu/hr.	Area ft <sup>2</sup>	Velocity ft/min	Air flow rate cfm	Humidity (% RH)		Temperature <sup>o</sup> ( C)		Enthalpy (h)		Diff.h	Btu/h 4.5*cfm*diffh	WC (kW)	EER (Btu/h/W)	kW/ton										
						R	S	R	S	R	S															
<p><i>Mistake number 138</i></p> <p>Separate the age of air conditioner as this list</p> <table border="0"> <tr> <td>1. - 3 years</td> <td rowspan="4">}</td> <td rowspan="4">Collect the data 10% of the number of each age. If the EER is low, the air conditioner should be replaced and show the data from auditing</td> </tr> <tr> <td>2. 3-5 years</td> </tr> <tr> <td>3. 5-6 years</td> </tr> <tr> <td>4. 6-7 years</td> </tr> <tr> <td>5. 7-8 years</td> <td rowspan="2">}</td> <td rowspan="2">Replace all air conditioner in this range</td> </tr> <tr> <td>6. 8 years</td> </tr> </table> <p>Collect the data from all air conditioner if there are only 30 sets in the organization</p>																	1. - 3 years	}	Collect the data 10% of the number of each age. If the EER is low, the air conditioner should be replaced and show the data from auditing	2. 3-5 years	3. 5-6 years	4. 6-7 years	5. 7-8 years	}	Replace all air conditioner in this range	6. 8 years
1. - 3 years	}	Collect the data 10% of the number of each age. If the EER is low, the air conditioner should be replaced and show the data from auditing																								
2. 3-5 years																										
3. 5-6 years																										
4. 6-7 years																										
5. 7-8 years	}	Replace all air conditioner in this range																								
6. 8 years																										

Split type air conditioner

Capacity	.....	Btu/h
Power	.....	watt
Volume of air flow rate	.....	cfm
Temperature and humidity of air return		
.....F, .....%		
Enthalpy : $h_r$	.....	Btu/lb
Temperature and humidity of air supply		
.....F, .....%		
Enthalpy : $h_s$	.....	Btu/lb
Cooling capacity	= $4.5 \times \text{cfm} \times (h_r - h_s)$	Btu/hr
	= $4.5 \times \dots \times (\dots)$	Btu/hr
	= .....	Btu/hr
Transform to kw of cooling	= $(\dots / 12000) \times 3.517$	kW
( 1 ton of fefrigerant = 3.517 kW)	= $(\dots / 12000) \times (\dots)$	kW
	= .....	kW
COP	= kW of Refrigerator / kW compressor	
	= $\dots / \dots$	
	= $\dots$	
EER	= (Btu/h)/watt	
	= $\dots / \dots$	
	= $\dots$	

**A. 3.1 Average illumination**

**Building ....**

**Floor ....**

Room	Maximum	Minimum	Average	Daylight
Average illumination				

Conclusion

The average illumination of organization

**A. 3.2 Drawing of illumination**

**A. 3.3 Picture of luminary in building**

**A.4 Conclusion of energy using**

*Mistake number 139*  
Use 1.45 kW/ton for calculation

**Air conditioning system**

Total capacity = ..... Btu/hr  
 = ..... Ton  
 Energy consumption = ..... x .....  
 = ..... kW  
 Percent of operation = ..... % (A)  
 Percent of compressor operation = ..... % (B)  
 Total operating factor = ..... % (A) x (B)  
 Working period = ..... x .....  
 Energy consumption = .....  
 = ..... kWh/year  
 Transform to percentage = .....  
 = ..... %

**Lighting system**

Load of lighting system = ..... kW  
 Using factor = ..... %  
 Working period = ..... hr/year  
 Energy consumption = .....  
 = ..... kWh/year  
 Transform to percentage = .....  
 = ..... %

Others = 100 - ..... - .....  
 = .....  
 = ..... %

Mistake number 141

OTTV calculation should be done although the non-air conditioning area because the heat transfer value is the property of building. It maybe benefit to the air conditioning system in the future



RTTV calculation before and after improving

*Mistake number 142*

If the insulation tiling measures cannot be implemented, the auditor should calculate the ceramic coating measure and show the RTTV after coating the ceramic.



Date .....

**Section 1 General Data**

1.1 Building name.....

1.2 Address.....

.....

Telephone number

Facsimile number

1.3 Type of building     Office                     Hotel                     Hospital  
     Shopping center     Educational institute     Others

1.4 Period of working.....hr/day.....day/year

1.5 Number of room or bed

(1) Number of room in hotel

(2) Number of bed in hospital

1.6 Area using in each month


(1) Working Hour  (hr)	(2) Area of building excluding car park area		(3) Hotel	(4) Hospital	
	Air conditioning m <sup>2</sup>	Non air conditioning m <sup>2</sup>	Percent of serviced room per month	Number of patient (bed-day)	Number of patient (man)
Building A        ... hr	.....	.....	-	-	-
Building B        ... hr	.....	.....	-	-	-
.....                ... hr	.....	.....	-	-	-
.....                ... hr	.....	.....	-	-	-


(1) No.	(2) Name	(3) Register Number	(4) Valid of authority	
			Start date	End date

## 2.1 Data of area in building

(1) Building name	(2) Number of floor	(3) Height of floor (m)	(4) Car park area (m <sup>2</sup> )	(5) Using area (m <sup>2</sup> )	(6) Area of air conditioning (m <sup>2</sup> )	(7) Proportional of transparent to overall area	(8) Age of Building (year)
Building...							
Building...							
Building...							
Total							
Total area of controlled building				m2			
Air conditioning area				m2			

## 2.2 Map of organization





Section 3

3.1 Electrical purchasing

Mistake number 141  
Use the data of the last month shown in table 2.2.1

(1) Purchasing

Normal rate	30,407.00	kWh
TOD rate	-	kWh

(2) Peak demand

Normal rate	-	kWh
TOD rate		

Period	kWh
1) .....	
2) .....	
3) .....	

3.2 Energy using in each system

**Mistake number 144**  
Use the data of the last month in table 2.2.1

(1) System	(2) Energy consumption (kWh)		(3) Percentage	(4) Remark
	Instrument	Assesment		
Air conditioning	-			
Lighting	-			
Others	-			
Total	-			

3.3 Fuel using

(1) Type of fuel	(2) Unit	(3) Volume	(4) Price (baht/unit)	(5) Cost of fuel (baht)	(6) Remark
1. Fuel oil	l				
2. Diesel oil	l				
3. Benzine oil	l				
4. Kerozene	l				
5. Liquid petroleum gas	kg				
6. Natural gas	million Btu				
7. Others	unit				
.....					
.....					
.....					
Total					

(1) Name of equipment	(2) Quantity of fuel			(3) Price (baht/unit)	(4) Cost of fuel (baht)	(5) Remark
	Type	Quantity	Unit			
Boiler						
Autoclave						
Water heater						
Autoclave						
Other equipments						
.....						
.....						
.....						
Total						

3.5 Energy using for electrical energy production

Generate only electrical energy

Generate electrical and thermal energy

(1) Capacity (kW)	(2) Quantity of main fuel consumption			(3) Hour of operating (hr)	(4) Quantity of production (kWh)	
	Type	Quantity	Unit		For using	For selling



Type of energy	Unit	Quantity	Average heating value (MJ/unit)	Quantity of auxiliary heating (MJ)
1. Purchased electricity	kwh		3.6	
2. Fuel oil	l			
3. Diesel oil	l			
4. Benzine oil	l			
5. Kerozie oil	l			
6. Liquid petroleum gas	kg			
7. Natural gas	million Btu			
8. Others	unit			
.....				
.....				
.....				
Total				

**Section 4 The machine installation for energy conservation**

4.1 Machine or equipment

**1. Transformer**

Item	Unit 1	Unit 2	Unit 3	Unit 4
Type of transformer	[ ] Dry type [ ] Oil type	[ ] Dry type [ ] Oil type	[ ] Dry type [ ] Oil type	[ ] Dry type [ ] Oil type
Capacity (kVA)				
High voltage (kV)				
Low voltage (V)				
Cooling system				
Producer				
Installed year				
Location				
Remark				

Unitary air conditioning system

Item	Unit 21	Unit 22	Unit 23	Unit 24
Type of air conditioner				
Capacity Btu/hr				
Electncal power (kw)				
Brand name				
Date of installation				
Location of using				
Remark				

(3) Central air conditioner

Item			
Type of chiller		<input type="checkbox"/> Water cooling <input type="checkbox"/> Air cooling	
Type of air compressor			
Capacity of air conditioner		ton/hr	
Capacity of air compressor		kW	
Type of water cooling equipment	Chilling water pump	kW	
		l/hr	
	Cooling water pump	kW	
		l/hr	
Cooling tower	kW		
Type of air cooling equipment	Chiller pump	kW	
		l/hr	
	Air cooling fan	kW	
Brand name of chiller			
Date of installation			
Location			
Remark			

(4) Lighting system

4.1 Fluorescent lamp

(1) Lamp	(2) Ballast	(3) Cover	(4) Lamp per Luminary	(5) Number of Luminary	(6) watt per lamp  (watt/luminary)	(7) Ballast lost  (watt/luminary)	(8) Total power (watt)	(9) Opeating hour (hr/day)
Fluorescent lamp 58 watt	<input type="checkbox"/> Hang <input type="checkbox"/> Recess <input type="checkbox"/> Others ..... .....	<input type="checkbox"/> Bare <input type="checkbox"/> Opal <input type="checkbox"/> Prismatic <input type="checkbox"/> Others ..... .....						
Fluorescent lamp 36 or 40 watt	<input type="checkbox"/> Hang <input type="checkbox"/> Recess <input type="checkbox"/> Others ..... .....	<input type="checkbox"/> Bare <input type="checkbox"/> Opal <input type="checkbox"/> Prismatic <input type="checkbox"/> Others ..... .....	<input type="checkbox"/> 36 watt <input type="checkbox"/> 40 watt	<input type="checkbox"/> 36 watt <input type="checkbox"/> 40 watt				
Fluorescent lamp 32 watt	<input type="checkbox"/> Hang <input type="checkbox"/> Recess <input type="checkbox"/> Others ..... .....	<input type="checkbox"/> Bare <input type="checkbox"/> Opal <input type="checkbox"/> Prismatic <input type="checkbox"/> Others ..... .....						
Fluorescent lamp 18,20 watt	<input type="checkbox"/> Hang <input type="checkbox"/> Recess <input type="checkbox"/> Others ..... .....	<input type="checkbox"/> Bare <input type="checkbox"/> Opal <input type="checkbox"/> Prismatic <input type="checkbox"/> Others ..... .....	<input type="checkbox"/> 18 watt <input type="checkbox"/> 20 watt	<input type="checkbox"/> 18 watt <input type="checkbox"/> 20 watt				

4.2 The improvement about the energy conservation

(1) Type of lamp	(2) Number of lamp	(3) Power (watt/lamp)	(4) Ballast loss (watt/lamp)	(5) Total power (watt)	(6) Operating hour (hr/day)
Incandescent					
.....watt					
.....watt					
Tungsten and halogen lamp					
.....watt					
.....watt					
Compact fluorescent					
.....watt					
.....watt					
High pressure mercury lamp					
.....watt					
.....watt					
Metalhidge lamp					
.....watt					
.....watt					
High pressure sodium lamp					
.....watt					
.....watt					
Low pressure sodium lamp					
.....watt					
.....watt					

(5) More than 5 kw consumed equipment

Item	Set 1	Set 2	Set 3	Set 4
Type of air conditioner				
capacity (kW)				
Voltage (V)				
Current (ampere)				
Phase				
Power factor (%)				
Efficiency (%)				
Date of installation				
Location				
Remark				

Item		Set 1	Set 2	Set 3
Type of boiler				
Designed capacity	Steam pressure			
	Evaporating rate			
Outside figure	Width (m)			
	Length (m)			
	Height (m)			
	Diameter (m)			
Heat transfer surface				
Type of used fuel				
Rate of fuel consumption				
Efficiency (%)				
Brand name				
Date of installation				
Location				
Remark				

## (7) Heat recovery system

Type of heat recovery	Condensate Recovery	The heat or heating gas recovery			Blow down system
		Condenser	Indoor	Stack	
Type of machine					
Type/model					
Number					
Temperature of recovery					
Percent of recovery					
Brand name					
Date of installation					
Remark					

Name of machine	autoclave	Condensator	Clothes dryer	Roll iron machine	Other
Type/model					
Number					
Pressure					
Quantity					
Brand name					
Date of installation					
Location					
Remark					

(9.1) Power generator

Item	Set 1	Set 2	Set 3	set 4
Type of engine				
Brake horse power				
rpm				
Type of fuel				
Stage of engine				
Brand name				
Date of installation				
Location				
Remark				

Item	Set 1	Set 2	Set 3	Set 4
Capacity (kW)				
Voltage (V)				
Current (amp)				
Power factor				
rpm				
Brand name				
Date of installation				
Location				
Remark				



Type and name of machine	Autoclave	Water heater	Distillation equipment	Clothes dryer	Other
Type/model					
Number					
Type of fuel					
Quantity of fuel consumption					
Brand name					
Date of installation					
Remark					

4.2 The improvement about the energy conservation

No.	Detail of improvement	Improving period		Investment (baht)	Saving			Remark
		Start Date	End Date		Type of energy	Number	Value (baht)	
Total								

Signature of cooperator

(.....)



Register Data

TSIC CODE .....	Mistake number 145	Put * - * in this line
Title of building .....	Mistake number 146	Such as "Ministry or Department"
Name of organization .....	Mistake number 147	Such as "Energy Development and Promoton"
Type of organization .....	Mistake number 148	Such as "There are only three kinds of building " hospital, education institute, and government organization"
Address .....		

Energy data

Peak demand .....	kW
Electrical energy .....	kW/year
Thermal energy .....	Million MJ/year
Date of data recording .....	
Year of construction .....	
<input type="checkbox"/> Old building	<input type="checkbox"/> New building

Name of cooperator .....

Register Data

Year of data recording	.....	<i>Mistake number 149</i>
TSIC CODE	.....	Use the data in latest year of recording
Name of organization	.....	<i>Mistake number 150</i>
Name of building	.....	Write the name of the building not organization
Number of building	.....	<i>Mistake number 151</i>
Date of recording	.....	Suppose 01, 02, ... for the building which has no number
Audit by CONSORTIUM.....		<i>Mistake number 152</i>
		Consortium mean the name of auditor

Old building

New building

1. Data of area in building

Number of floor	.....	floors
Height of each floor	.....	m
Car park area	.....	m <sup>2</sup>
Total using area	.....	m <sup>2</sup>
Air conditioning area	.....	m <sup>2</sup>
Transparent area per overall area	.....	%
Age of building	.....	year

Register Data

*Mistake number 153* Use the data of organization

2. Electrical energy using

System	Energy using (kwh)		Percentage
	Instrument	Assesment	
Air conditioning	-		
Lighting	-		
Others	-		

3. Energy conservation in building except air conditioning system

No.	Measure	before improving	after improving	Unit
1	OTTV			W/m <sup>2</sup>
2	RTTV			W/m <sup>2</sup>
3	Lighting system index			W/m <sup>2</sup>

4. Measures of air conditioning system

No.	Capacity (ton)	Type	Number	Total (ton)	kw/ton

*Mistake number 154*

Write the data of all improved air conditioner

Register Data

Suggestion for energy conservation

Measures	Investment (baht)	Saving			Saving (baht)	
		kWh	LOE	GJ		
1. Air conditioning system 1.1 High EER air conditioner replacement						
2. Envelope system 2.1 Film coating 2.2 Insulation tiling 2.3 Ceramic coating		<div style="border: 1px solid black; padding: 2px;"> <i>Mistake number 155</i>                      kWh X 3.6 36 6 = LOE                 </div> <div style="border: 1px solid black; padding: 2px; margin-top: 5px;"> <i>Mistake number 156</i>                      kWh X 3 6 1000 = GJ                 </div>				
3. Lighting system 3.1 Compact fluorescent replacement 3.2 Reflector luminary replacement						

Measures	System	Payback Period (year)	FIRR(%)	EIRR(%)
High EER air conditioner replacement	Air conditioning		-	
Film coating	Envelope		-	
Insulation tiling	Envelope		-	
Ceramic coating	Envelope		-	
Compact fluorescent replacement	Lighting		-	
Reflector luminary replacement	Lighting		-	
Electronics ballast replacement	Lighting		-	

## Vita

My name is Kua-anan Techato. I was born on the first of April 1974 at Amphur Muang, Yala province. I graduated in bachelor degree of engineering from mechanical engineering department, faculty of engineering, Prince of Songkhla University in year 1995. Now I am a project engineer in the Energy Conservation Center of Thailand and Energy Efficiency Institute (Thailand).

